



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CUCAMONGA RIDGE INC			REINSPECTION DATE Not Specified	INSPECTOR Shannon Johnson	DATE 10/23/2015
LOCATION 8717 FOOTHILL BL, RANCHO CUCAMONGA, CA 91730			PERMIT EXPIRATION 5/31/2016	IDENTIFIER: Spa SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 10:01 AM	TIME OUT 10:32 AM	FACILITY ID FA0010720	RELATED ID PR0013990	PE 3623	RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

88
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	103.0
observed flow (gpm)	No Data
required flow (gpm)	104
volume (gal)	3,108
area (sq ft)	107
occupancy	10

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K536 Enclosure – Critical – Fencing/Enclosure **⚠ CRITICAL ⚠**

POINTS 5	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3119B	Inspector Comments: Observed multiple areas of the enclosure of this pool/spa that have gaps greater than four inches between the bottom of the enclosure and the ground below. All of these gaps must be eliminated immediately. A follow up inspection will be conducted regarding this violation.
---------------------------	--	---

Violation Description: The enclosure shall have a minimum effective perpendicular height of 5 feet. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch (102 mm) diameter sphere. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children. Chain link may be used, provided that the openings are not greater than 1¼ inches (44 mm) measured horizontally.

36K527 Safety – Safety signs

POINTS 1	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3120B	Inspector Comments: Observed no safety sign on the easternmost entrance gate stating, "Keep Gate Closed".
---------------------------	--	--

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CUCAMONGA RIDGE INC	DATE 10/23/2015
LOCATION 8717 FOOTHILL BL, RANCHO CUCAMONGA, CA 91730	INSPECTOR Shannon Johnson

36K554 Equipment - Pressure/Vacuum gauge requirements

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed no marking for the clean start up pressure on the pressure gauge located on the filter.
	Not In Compliance	
	Violation Reference - CCR 24 - 3125B.2	

Violation Description: A pressure and vacuum gauge shall be provided for each pump system. Each gauge shall have a scale range approximately 1 ¼ times the maximum anticipated working pressure or vacuum and shall be accurate within 2 percent of scale. The pressure gauge located on the filter shall be marked with the clean start up pressure reading.

36K556 Equipment – Plumbing labeled

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed no directional symbols on piping within the equipment enclosure.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.

36K562 Skimmers - Pool skimming systems

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed no weir within the skimmer.
	Not In Compliance	
	Violation Reference - CCR - 3136B	

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.

36K582 Maintenance - Public pool site maintenance

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the flow meter to be inoperable
	Not In Compliance	
	Violation Reference - HSC - 65535	

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

36K588 Restrooms - Toilet facilities/Showers

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the shower to be inoperable at this time.
	Not In Compliance	
	Violation Reference - CCR - 3116B	

Violation Description: Separate toilet facilities shall be provided for each sex. One toilet shall be provided for every 60 women or less and one toilet plus one urinal for every 75 men or less. One lavatory shall be provided for every 80 pool users.

Shower and dressing facilities shall be provided for users of a pool.

36K589 Ancillary - Cleanliness/Supplies

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed no toilet paper within either public restroom.
	Not In Compliance	
	Violation Reference - HSC - 65551	Observed no available paper towels within the women's public restroom.

Violation Description: (a) The pool operator shall keep clean and free of slime, algae, litter, and vermin all ancillary facilities, including, but not limited to, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

(b) Except for deck showers, all showers provided for pool users as required by Chapter 31B, Title 24, California Code of Regulations shall have soap in dispensers or containers.

(c) For toilet facilities, toilet tissue, handwashing soap, and paper towels or hot air blowers, shall be provided in permanently installed dispensing devices.

(d) The pool operator shall provide and maintain, in a clean and sanitary condition, a minimum of one waste receptacle in each toilet facility.

(e) Wooden slats, duckboards, and footbaths are prohibited.



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

<small>FACILITY NAME</small> CUCAMONGA RIDGE INC	<small>DATE</small> 10/23/2015
<small>LOCATION</small> 8717 FOOTHILL BL, RANCHO CUCAMONGA, CA 91730	<small>INSPECTOR</small> Shannon Johnson

Overall Inspection Comments

A follow up inspection will be conducted on 11-23-15 to ensue all gaps greater than four inches between the bottom of the enclosure and the ground below have been eliminated. If compliance has not be achieved by this time, a charged inspection will ensue.

Signature(s) of Acknowledgement

SNC

NAME:
TITLE:

Total # of Images: 0