



**Public Health**  
**Environmental Health Services**


www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME VAN LEUVEN 14		DATE 7/16/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2016
LOCATION 25247 VAN LEUVEN ST, LOMA LINDA, CA 92354			INSPECTOR Veronica Vazquez	
MAILING ADDRESS 715 E. BRIER DR, SAN BERNARDINO CA 92408			IDENTIFIER: Pool	
TIME IN 11:38 AM	TIME OUT 12:00 PM	FACILITY ID FA0004338	RELATED ID PR0015695	PE 3620
			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	16

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K994 Reinspection**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: Observed pool gate mesh repaired.  Immediately repair/replace pool light.
	Not In Compliance Violation Reference - HSC	

**Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**36K522 Safety – Critical – Unsafe or hazardous conditions** ⚠️ CRITICAL ⚠️

<b>POINTS</b> <b>5</b>	Compliance Date: Not Specified	Inspector Comments: Pool is hereby closed due to electrical hazard. Posted closure sign. Closed pool gate with zip tie. Contact the County of San Bernardino, Division of Environmental Health Services (DEHS) when compliance is reached. Maintain pool closed until re-opened by DEHS inspector.
	Not In Compliance Violation Reference - HSC - 65545	

**Violation Description:** A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent.

**36K524 Safety – Critical – Electrical hazards; GFCI** ⚠️ CRITICAL ⚠️

<b>POINTS</b> <b>5</b>	Comply by: 7/17/2015	Inspector Comments: Observed pool light fixture with water inside. Observed no Ground Fault Circuit Interrupter (GFCI) available for pool light.  Immediately repair/replace pool light and provide a (GFCI).
	Not In Compliance Violation Reference - HSC - 116049	

**Violation Description:** The design and installation of all underwater lighting systems, operating at more than 15 volts, supplied from a branch circuit either directly or by way of a transformer, shall be installed in a public swimming pool so that there is no shock hazard with any likely combination of fault conditions during normal use, and shall comply with both of the following requirements:

- (1) An approved ground-fault circuit interrupter shall be installed in the branch circuit that supplies all fixtures operating at more than 15 volts.
- (2) Only approved underwater lighting fixtures shall be used and no lighting fixtures shall be installed for operations at more than 150 volts between conductors.

**Overall Inspection Comments**

Call Veronica Vazquez at (800) 442-2283 with questions.

**Signature(s) of Acknowledgement**



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME VAN LEUVEN 14	DATE 7/16/2015
LOCATION 25247 VAN LEUVEN ST, LOMA LINDA, CA 92354	INSPECTOR Veronica Vazquez

NAME:  
TITLE:

Total # of Images: 0