



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SHADY TRAILS PARKHOUSE		REINSPECTION DATE Not Specified	INSPECTOR Lizeth Lopez	DATE 9/16/2016
LOCATION 15977 PARKSIDE WY, FONTANA, CA 92336		PERMIT EXPIRATION 8/31/2017	IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 2:35 PM	TIME OUT 3:39 PM	FACILITY ID FA0024697	RELATED ID PR0032112	PE 3620
		RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

91
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K995 Permit - Suspension **⚠ CRITICAL ⚠**

POINTS NA	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC	Inspector Comments: Pool permit temporarily suspended due to electrical hazard. Closure sign posted. Re-inspection required to verify compliance before pool can re-open. Call (800) 442-2283 for re-inspection when critical violations have been corrected.
----------------------------	---	---

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K524 Safety – Critical – Electrical hazards; GFCI **⚠ CRITICAL ⚠**

POINTS 5	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC - 116049	Inspector Comments: Observed half of the pool lights and ground-fault circuit interrupter (GFCI) operating. The other half of the pool has operating lights, but the GFCI is not operating. The pool lights are connected to two different GFCI systems. Ensure the ground-fault circuit interrupter is operating at all times. Re-inspection required. Pool permit suspended temporarily. Closure sign posted.
---------------------------	--	--

Violation Description: The design and installation of all underwater lighting systems, operating at more than 15 volts, supplied from a branch circuit either directly or by way of a transformer, shall be installed in a public swimming pool so that there is no shock hazard with any likely combination of fault conditions during normal use, and shall comply with both of the following requirements:

- (1) An approved ground-fault circuit interrupter shall be installed in the branch circuit that supplies all fixtures operating at more than 15 volts.
- (2) Only approved underwater lighting fixtures shall be used and no lighting fixtures shall be installed for operations at more than 150 volts between conductors.

36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8

POINTS 1	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC - 65530	Inspector Comments: Observed pH to be measured at 7.9. Maintain pH between the required range of 7.2 and 7.8.
---------------------------	---	---

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SHADY TRAILS PARKHOUSE	DATE 9/16/2016
LOCATION 15977 PARKSIDE WY, FONTANA, CA 92336	INSPECTOR Lizeth Lopez

36K518 Water Quality – Cyanuric acid concentration

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid concentration to be measured "[above] range". Maintain cyanuric acid concentration below the maximum of 100.0 ppm.
	Not In Compliance	
	Violation Reference - HSC - 65530	

Violation Description: The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.

36K552 Equipment - Flow meter provided

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed non-functional flow meter. Repair or replace flow meter. Ensure flow rate meets the turnover time requirements.
	Not In Compliance	
	Violation Reference - CCR 24 - 3125B.3	

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow and installed according to the manufacturer's written instructions with increments in the range of normal flow.

36K582 Maintenance - Public pool site maintenance

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed loose hand rails by the deep end. Tighten hand rails.
	Not In Compliance	
	Violation Reference - HSC - 65535	

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

36K596 Permit - Public Pool Closure

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Pool is closed. Pool permit temporarily suspended due to electrical hazard. Closure sign posted. Re-inspection required to verify compliance before pool can re-open. Call (800) 442-2283 for re-inspection when critical violations have been corrected.
	Not In Compliance	
	Violation Reference - HSC - 65545	

Description: A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.

Overall Inspection Comments

Pool permit suspended due to electrical hazard. Closure sign posted.

Re-inspection required to verify compliance before pool can re-open. Call (800) 442-2283 for re-inspection when critical violations have been corrected.

Signature(s) of Acknowledgement

NAME: Mario Lopez
TITLE: Facility Coordinator

Total # of Images: 0