



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME COLONY RIDGE APARTMENTS		DATE 6/2/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2015
LOCATION 17400 ARROW, FONTANA, CA 92335			INSPECTOR Isaac Gebreslassie	
MAILING ADDRESS 1225 N GROVE ST, ANAHEIM CA 92806			IDENTIFIER: Spa	
			SERVICE: 001 - INSPECTION - ROUTINE	
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	
TIME IN 11:24 AM	TIME OUT 12:11 PM	FACILITY ID FA0005872	RELATED ID PR0014936	PE 3623




**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**97**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	100.0
observed flow (gpm)	80
required flow (gpm)	34
volume (gal)	1,009
area (sq ft)	39
occupancy	3

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K554 Equipment - Pressure/Vacuum gauge requirements**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Provide clean start up pressure on filter pressure gage. Observed missing.
	Not In Compliance	
	Violation Reference - CCR 24 - 3125B.2	

**Violation Description:** A pressure and vacuum gauge shall be provided for each pump system. Each gauge shall have a scale range approximately 1 ¼ times the maximum anticipated working pressure or vacuum and shall be accurate within 2 percent of scale. The pressure gauge located on the filter shall be marked with the clean start up pressure reading.

**36K576 Maintenance – Operation/Incident records**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no daily records of of chemical testing and maintenance missing. Provide as described below.
	Not In Compliance	
	Violation Reference - HSC - 65523	

**Violation Description:** The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

**36K584 Maintenance - Operating procedures/Manufacturers' instructions**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no operating procedures or manufacturers instructions on site. Keep these manuals for maintenance and operation of all mechanical or electrical equipment.
	Not In Compliance	
	Violation Reference - HSC - 65521	

**Violation Description:** The pool operator shall maintain pool operating procedures at the public pool site for use by the pool operator and for inspection by the enforcing agent. The pool operator shall maintain manufacturers' instructions for the operation and maintenance for all mechanical and electrical equipment and water treatment systems at the public pool site for use by the pool operator and for inspection by the enforcing agent.

**Overall Inspection Comments**

No summary comments have been made for this inspection.



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME COLONY RIDGE APARTMENTS	DATE 6/2/2015
LOCATION 17400 ARROW , FONTANA, CA 92335	INSPECTOR Isaac Gebreslassie

**Signature(s) of Acknowledgement**

Gwen

NAME: Gwen  
TITLE: manager

Total # of Images: 0