



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME MT VIEW GARDENS		DATE 5/7/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 10877 LORO VERDE, LOMA LINDA, CA 92354			INSPECTOR Veronica Vazquez	
MAILING ADDRESS PO BOX 7429, REDLANDS CA 92375-0429			IDENTIFIER: West Spa	
TIME IN 3:30 PM			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT 3:59 PM			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
FACILITY ID FA0008693			ACTION: 03 - REINSPECTION REQUIRED	
RELATED ID PR0013553			PE 3623	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

93

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	100.0
observed flow (gpm)	No Data
required flow (gpm)	56
volume (gal)	1,682
area (sq ft)	81
occupancy	8

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K540 Enclosure – Critical – Gates and doors self-closing and self-latching



POINTS 5	Comply by: 5/14/2015	Inspector Comments: Provide emergency exit pool area without key.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.

36K518 Water Quality – Cyanuric acid concentration

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid above 100 ppm.
	Not In Compliance	
	Violation Reference - HSC - 65530	

Violation Description: The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.

36K582 Maintenance - Public pool site maintenance

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Repair/replace flow meter for spa. Observed flow meter stuck at zero GPM.
	Not In Compliance	Repair/replace skimmer basket. Observed skimmer basket broken.
	Violation Reference - HSC - 65535	Provide weir in spa skimmer. Observed missing.

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

Overall Inspection Comments

Call Veronica Vazquez at (800) 442-2283 with questions.

Signature(s) of Acknowledgement



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME MT VIEW GARDENS	DATE 5/7/2015
LOCATION 10877 LORO VERDE , LOMA LINDA, CA 92354	INSPECTOR Veronica Vazquez

NAME:
TITLE:

Total # of Images: 0