



Public Health
Environmental Health Services




www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME KENDALL PALMS APARTMENTS		DATE 6/23/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 8/31/2015
LOCATION 3943 N H ST, SAN BERNARDINO, CA 92404			INSPECTOR Tia Wilson	
MAILING ADDRESS 9201 SUNSET BL STE 905, LOS ANGELES CA 90069			IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 008 - INSPECTION - ATTEMPTED	
TIME IN 2:19 PM	TIME OUT 2:31 PM	FACILITY ID FA0008920	RELATED ID PR0013853	PE 3620
			RESULT: 00 - NOT APPLICABLE	
			ACTION: 00 - NOT APPLICABLE	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Unable to access pool due to locked gate. Observed office not open but operating hours listed M-F 9:00am- 3:00 pm.
	Not In Compliance	
	Violation Reference - HSC	

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

Another inspection will be attempted at a later date.

Signature(s) of Acknowledgement

NAME: Signature not available
TITLE:

Total # of Images: 0