



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>BROOKSIDE PARK APTS</b>		DATE <b>6/2/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>6/30/2015</b>
LOCATION <b>1264 BROOKSIDE AV, REDLANDS, CA 92373</b>			INSPECTOR <b>Yvette Velasco</b>	
MAILING ADDRESS <b>1350 MILBURN AV, REDLANDS CA 92373</b>			IDENTIFIER: Spa C - South West	
			SERVICE: 001 - INSPECTION - ROUTINE	
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	
TIME IN <b>4:00 PM</b>	TIME OUT <b>4:20 PM</b>	FACILITY ID <b>FA0008759</b>	RELATED ID <b>PR0014276</b>	PE <b>3623</b>




**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**97**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	102.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K504 Water Quality – Non-Critical – Disinfectant level low**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine at 0.4ppm.
	Not In Compliance	Maintain free chlorine in spa at 3.0-10.0ppm.
	Violation Reference - HSC - 65529	

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

**36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed pH at 8.0.
	Not In Compliance	Maintain pH at 7.2-7.8.
	Violation Reference - HSC - 65530	

**Violation Description:** The pool operator shall maintain public pool water at pH 7.2 to 7.8.

**36K546 Equipment – Non-Critical - Water treatment system operation**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed non-functional flow meter.
	Not In Compliance	Repair as soon as possible.
	Violation Reference - HSC - 65525	

**Violation Description:** The pool operator shall operate pumps, filters, disinfectant and chemical feeders, flow indicators, gauges, recirculation systems, disinfection systems, and all parts of the water treatment system whenever the public pool is available for use, and at such additional times and periods as may be necessary to maintain clean pool water, clear pool water, and the disinfection standards required in section 65529 [Health and Safety Code].

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>BROOKSIDE PARK APTS</b>	DATE <b>6/2/2015</b>
LOCATION <b>1264 BROOKSIDE AV, REDLANDS, CA 92373</b>	INSPECTOR <b>Yvette Velasco</b>

NAME:  
TITLE:

**Total # of Images: 0**