



**Public Health**  
Environmental Health Services



www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>EUREKA MANOR</b>		DATE <b>7/2/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION
LOCATION <b>1525 E EUREKA ST, SAN BERNARDINO, CA 92404</b>			INSPECTOR <b>Anies Kondoker</b>	
MAILING ADDRESS <b>1525 E EUREKA ST, SAN BERNARDINO, CA 92404</b>			IDENTIFIER: None	
TIME IN <b>5:03 PM</b>	TIME OUT <b>5:04 PM</b>	FACILITY ID <b>FA0008381</b>	RELATED ID <b>CO0051416</b>	PE <b>3620</b>
			SERVICE: 004 - COMPLAINT - INITIAL RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K999 Complaint Inspection**

POINTS <b>NA</b>	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	
	Violation Reference - HSC	

**Description:** A complaint report has been received by Environmental Health.

**Overall Inspection Comments**

The pool and spa water is no longer green.  
No access to the pool enclosure. Manager is not on site at this time.  
Bottom of the pool was not visible from outside pool enclosure.  
Observed good spa water clarity.  
No access to equipment room. Sound of pump motor could be heard from outside.  
A resident stated that a pool service person has not come to service the pool yet.

Call health dept prior opening.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:  
Total # of Images: 0