



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME MOUNTAIN VIEW SPRING ESTATES HOA		DATE 8/27/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2016
LOCATION 1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410			INSPECTOR John Babalola	
MAILING ADDRESS 1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410			IDENTIFIER: Pool	
TIME IN 4:00 PM	TIME OUT 4:39 PM	FACILITY ID FA0008858	RELATED ID PR0014215	PE 3620
			SERVICE: 001 - INSPECTION - ROUTINE RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.



90

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	0
required flow (gpm)	57
volume (gal)	20,655
area (sq ft)	648
occupancy	32

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:
 1. Meet the latest ANSI/APSP-16 performance standard
 2. Be rated for the maximum designed flow-rate of the pump
 Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K502 Water Quality - Critical – Disinfectant level ⚠️ CRITICAL ⚠️

POINTS
5

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC - 65529

Inspector Comments: The free chlorine level is observed at 0.0 ppm (zero). Provide at least 2.0 ppm.
 Note: The pool is hereby ordered closed until the chlorine level is adjusted to the legal limits. Call (800) 442-2283 for a re-inspection.

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

36K556 Equipment – Plumbing labeled

POINTS
1

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR 24 - 3120B

Inspector Comments: No flow direction labels observed in the equipment room. Provide the labels.

Violation Description: The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.



Public Health Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME MOUNTAIN VIEW SPRING ESTATES HOA	DATE 8/27/2015
LOCATION 1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410	INSPECTOR John Babalola

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K572 Maintenance – Pool shell cleanliness; slime and algae

POINTS
1

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 65533

Inspector Comments: Observed yellow stains on the sides of the pool shell. Maintain clean.

Violation Description: (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash, or leaves, to accumulate in the public pool. The pool operator shall ensure that water levels are maintained and operated to remove such material continuously through the pool skimming system in accordance with section 3136B, Title 24, California Code of Regulations.

(b) The pool operator shall clean the bottom, sides, and other surfaces of the public pool as often as necessary to keep the bottom, sides, and public pool surfaces clean and free of slime and algae.

36K576 Maintenance – Operation/Incident records

POINTS
1

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 65523

Inspector Comments: No daily records of pH, chlorine, and equipment readings observed. Maintain the records.

Violation Description: The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

36K582 Maintenance - Public pool site maintenance

POINTS
1

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 65535

Inspector Comments: Repair/replace the non-functional flow meter

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

36K582 Maintenance - Public pool site maintenance

POINTS
1

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 65535

Inspector Comments: Refill the empty automatic chlorinator.

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME MOUNTAIN VIEW SPRING ESTATES HOA	DATE 8/27/2015
LOCATION 1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410	INSPECTOR John Babalola

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K596 Permit - Public Pool Closure

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 65545

Inspector Comments: The pool is hereby ordered closed until the chlorine level is adjusted to the legal limits. Call (800) 442-2283 for a re-inspection.

Description: A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.

Overall Inspection Comments

RE: Closure

The pool is hereby ordered closed until the chlorine level is adjusted to the legal limits.
Call (800) 442-2283 for a re-inspection.

Closed sign posted.

Signature(s) of Acknowledgement

NAME: Benjamin Haro
TITLE: office manager

Total # of Images: 0