



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CENTRAL PARK EAST APARTMENTS			REINSPECTION DATE Not Specified	INSPECTOR Chris Nwadike	DATE 10/20/2015
LOCATION 1129 E CENTRAL AV, REDLANDS, CA 92373			PERMIT EXPIRATION 10/31/2015	IDENTIFIER: Pool	
TIME IN 9:58 AM	TIME OUT 10:41 AM	FACILITY ID FA0005867	RELATED ID PR0015579	PE 3620	SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN




RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	32
volume (gal)	11,835
area (sq ft)	526
occupancy	13

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: The entry gate has been repaired - It can now self-close and self-latch. The health permit is reinstated and pool re-opened for use.
	Not In Compliance	
	Violation Reference - HSC	

Description: The health permit to operate is hereby reinstated and facility may open.

36K504 Water Quality – Non-Critical – Disinfectant level low

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed chlorine level at 10.1ppm. Maintain chlorine level between 2.0ppm and 10.0ppm.
	Not In Compliance	
	Violation Reference - HSC - 65529	

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

36K518 Water Quality – Cyanuric acid concentration

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid level at 107.00ppm. Maintain below 100.0ppm (under 50.0ppm preferred).
	Not In Compliance	
	Violation Reference - HSC - 65530	

Violation Description: The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement



Public Health
Environmental Health Services

www.SBCounty.gov
www.SBCounty.gov/dph/dehs

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

<small>FACILITY NAME</small> CENTRAL PARK EAST APARTMENTS	<small>DATE</small> 10/20/2015
<small>LOCATION</small> 1129 E CENTRAL AV, REDLANDS, CA 92373	<small>INSPECTOR</small> Chris Nwadike

NAME:
TITLE:

Total # of Images: 0