



**Public Health**  
**Environmental Health Services**

www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME WATERSTONE ALTA LOMA		DATE 7/20/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 11/30/2015
LOCATION 9600 19TH ST, RANCHO CUCAMONGA, CA 91701			INSPECTOR Dior Porter	
MAILING ADDRESS 9600 19TH ST, ALTA LOMA CA 91737			IDENTIFIER: Pool	
TIME IN 10:35 AM			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT 11:05 AM			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
FACILITY ID FA0005424			ACTION: 01 - NO FURTHER ACTION REQUIRED	
RELATED ID PR0015592			PE 3620	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




**99**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	80
required flow (gpm)	50
volume (gal)	18,000
area (sq ft)	No Data
occupancy	30

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K518 Water Quality – Cyanuric acid concentration**

<b>POINTS</b>  <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Measured cyanuric acid above 100ppm. Cyanuric acid is not to exceed 100ppm
	Not In Compliance	
	Violation Reference - HSC - 65530	

**Violation Description:** The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0