



Public Health
Environmental Health Services




www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME MOUNTAIN VIEW SPRING ESTATES HOA		DATE 6/8/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410			INSPECTOR John Babalola	
MAILING ADDRESS 1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410			IDENTIFIER: Pool	
TIME IN 2:22 PM	TIME OUT 2:40 PM	FACILITY ID FA0008858	RELATED ID PR0014215	PE 3620
SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED				

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	100
required flow (gpm)	57
volume (gal)	20,655
area (sq ft)	648
occupancy	32

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: All violations noted on the inspection report of 6-2-15 have been corrected. Good compliance.
	Not In Compliance	
	Violation Reference - HSC	

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: Benjamin Haro
TITLE: Office manager

Total # of Images: 0