



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME VILLA GABRIEL HOA			DATE 7/22/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2015
LOCATION 8300 GABRIEL DR, RANCHO CUCAMONGA, CA 91730				INSPECTOR Shannon Johnson	
MAILING ADDRESS PO BOX 5022, UPLAND CA 91785				IDENTIFIER: Spa	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 11:51 AM	TIME OUT 12:30 PM	FACILITY ID FA0004427	RELATED ID PR0015419	PE 3623	RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




98

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	101.0
observed flow (gpm)	45
required flow (gpm)	61
volume (gal)	1,851
area (sq ft)	90
occupancy	9

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K538 Enclosure – Non-Critical – Fencing/Enclosure

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed gaps greater than 4 inches between the bottom of the enclosure and the ground below near the pump enclosure, adjacent to the pool house, and near the mailboxes for the residents of this location. All gaps greater than 4 inches must be eliminated. A follow up inspection will be conducted to ensure compliance regarding this matter.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

Violation Description: The enclosure shall have a minimum effective perpendicular height of 5 feet. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch (102 mm) diameter sphere. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children. Chain link may be used, provided that the openings are not greater than 1¾ inches (44 mm) measured horizontally.

36K562 Skimmers - Pool skimming systems

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed no check valve within the skimmer at the equalizer line.
	Not In Compliance	
	Violation Reference - CCR - 3136B	

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.

Overall Inspection Comments

A follow up inspection will be conducted on 8-5-15 to ensure that all gaps greater than 4 inches have been eliminated between the bottom of the enclosure and the ground below. Failure to achieve compliance regarding this matter by this time will result in a charged inspection to ensue.

Signature(s) of Acknowledgement



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME VILLA GABRIEL HOA	DATE 7/22/2015
LOCATION 8300 GABRIEL DR, RANCHO CUCAMONGA, CA 91730	INSPECTOR Shannon Johnson

SNC

NAME:
TITLE:

Total # of Images: 0