





RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SUNSET VILLAGE CONDOS		REINSPECTION DATE Not Specified		INSPECTOR Patrick Baccari	DATE 9/22/2015
LOCATION 16770 SAN BERNARDINO AV, FONTANA, CA 92335				PERMIT EXPIRATION 6/30/2016	IDENTIFIER: pool
TIME IN 9:14 AM	TIME OUT 9:30 AM	FACILITY ID FA0008614	RELATED ID PR0014387	PE 3620	SERVICE: 008 - INSPECTION - ATTEMPTED RESULT: 00 - NOT APPLICABLE ACTION: 00 - NOT APPLICABLE

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K572 Maintenance – Pool shell cleanliness; slime and algae

POINTS
1

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 65533

Inspector Comments: Observed algae was present on pool shell but main drains are still visible.
Vacuum pool shell to remove algae and debris from pool shell.
Remove rocks and debris from pool enclosure area.
Contact San Bernardino County Environmental Health to perform plan check review inspection to re-open facility, 1 800 442 2282.

Violation Description: (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash, or leaves, to accumulate in the public pool. The pool operator shall ensure that water levels are maintained and operated to remove such material continuously through the pool skimming system in accordance with section 3136B, Title 24, California Code of Regulations.

(b) The pool operator shall clean the bottom, sides, and other surfaces of the public pool as often as necessary to keep the bottom, sides, and public pool surfaces clean and free of slime and algae.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:
Total # of Images: 0