



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME JUNIPER VILLAGE		DATE 6/3/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 16700 MARYGOLD AV, FONTANA, CA 92335			INSPECTOR Patrick Baccari	
MAILING ADDRESS 16700 MARYGOLD AV, FONTANA, CA 92335			IDENTIFIER: Spa	
			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 1:30 PM	TIME OUT 1:55 PM	FACILITY ID FA0004868	RELATED ID PR0015974	PE 3623
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	




RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

98
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	60
required flow (gpm)	37
volume (gal)	1,139
area (sq ft)	63
occupancy	6

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K548 Equipment - General Requirements - System Description

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Provide cleaning to equipment enclosure area.
	Not In Compliance	
	Violation Reference - CCR 24 - 3123B.1	

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The system shall consist of pumps, filters, chemical feeders, skimmers or perimeter overflow systems, valves, pipes, connections, fittings and appurtenances.

36K574 Maintenance – Test kit

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Maintain daily log of water chemistry.
	Not In Compliance	
	Violation Reference - HSC - 65529	

Violation Description: The pool operator shall maintain a test kit for measuring the disinfectant residual, pH, and, if used, cyanuric acid concentration at the public pool. This test kit shall be available for use by the pool operator and the enforcing agent at all times the public pool is in use. The chlorine or bromine test kit shall be the diethyl-p-phenylenediamine (DPD) type or otherwise be capable of testing free-halogen residual.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: Karla Bazan
TITLE:

Total # of Images: 0