



Public Health
Environmental Health Services



www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CALIFORNIA ATHLETIC CLUB		DATE 3/16/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION
LOCATION 9120 HAVEN , RANCHO CUCAMONGA, CA 91730			INSPECTOR Nick Thalasinios	
MAILING ADDRESS 9120 HAVEN , RANCHO CUCAMONGA, CA 91730			IDENTIFIER: None	
TIME IN 10:35 AM	TIME OUT 12:05 PM	FACILITY ID FA0005871	RELATED ID CO0050158	PE 3622
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT SERVICE: 004 - COMPLAINT - INITIAL RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDE / FACILITY CLOSED				

RECREATIONAL HEALTH - Public Pool - Initial Spa at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K995 Permit - Suspension



POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed a main drain cover is not fastened in place.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K999 Complaint Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: COMPLAINANT STATED POOL HAS NOT BEEN WORKING FOR COUPLE OF WEEKS AND BATHROOMS ARE DIRTY
	Not In Compliance	
	Violation Reference - HSC	

Description: A complaint report has been received by Environmental Health.

Overall Inspection Comments

Observed the spa pool heater is reportedly being fixed, but the spa pool was open to the public. The toilet room was clean.

The Permit is SUSPENDED and the Spa Pool CLOSED. Contact EHS for reinspection.

Signature(s) of Acknowledgement

NAME:
TITLE:

Photo Attachments:
No Photo Attachments