



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>MT VIEW GARDENS</b>		DATE <b>5/7/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>6/30/2015</b>
LOCATION <b>10877 LORO VERDE, LOMA LINDA, CA 92354</b>			INSPECTOR <b>Veronica Vazquez</b>	
MAILING ADDRESS <b>PO BOX 7429, REDLANDS CA 92375-0429</b>			IDENTIFIER: East Pool	
			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN <b>4:00 PM</b>	TIME OUT <b>4:34 PM</b>	FACILITY ID <b>FA0008693</b>	RELATED ID <b>PR0013550</b>	PE <b>3620</b>
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 14 - PERMIT SUSPD / FACILITY CLOSED FENCI	




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**94**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

<b>Ideal</b>
<b>In Compliance</b>
<b>Not in Compliance</b>



temperature (°F)	No Data
observed flow (gpm)	40
required flow (gpm)	103
volume (gal)	37,125
area (sq ft)	900
occupancy	45

**IMPORTANT: Replacement of Suction Outlet Covers**

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K995 Permit - Suspension**



POINTS <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Pool is hereby closed. Posted closure sign for pool. Contact the County of San Bernardino, Division of Environmental Health Services (DEHS) when compliance is reached. Maintain pool closed until re-opened by DEHS inspector. Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K991 Permit Investigation**

POINTS <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Obtain valid transfer of ownership and health permit.  Observed pool under new management. Contact Division of Environmental Health Services to update information.
	Not In Compliance	
	Violation Reference - HSC	

**Description:** Obtain a valid health permit within 3 days or as specified to avoid facility closure and/or other possible legal action.

**36K540 Enclosure – Critical – Gates and doors self-closing and self-latching**



POINTS <b>5</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observe main pool gate not self closing and latching. Posted closure sign. Closed pool with zip tie.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.



**Public Health**  
**Environmental Health Services**

www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>MT VIEW GARDENS</b>	DATE <b>5/7/2015</b>
LOCATION <b>10877 LORO VERDE , LOMA LINDA, CA 92354</b>	INSPECTOR <b>Veronica Vazquez</b>

**IMPORTANT: Replacement of Suction Outlet Covers**

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K582 Maintenance - Public pool site maintenance**

<b>POINTS</b>  <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Provide paper towels in men and women restroom. Observed none.
	Not In Compliance	
	Violation Reference - HSC - 65535	

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

**36K596 Permit - Public Pool Closure**

<b>POINTS</b>  <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Pool is hereby closed due to enclosure gate not self closing and latching.
	Not In Compliance	
	Violation Reference - HSC - 65545	

**Description:** A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.

**Overall Inspection Comments**

Call Veronica Vazquez at (800) 442-2283 with questions.

**Signature(s) of Acknowledgement**

NAME:  
 TITLE:

Total # of Images: 0