



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME LA FITNESS		DATE 7/13/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 2/28/2016
LOCATION 16289 SIERRA LAKES PKWY, FONTANA, CA 92335			INSPECTOR Isaac Gebreslassie	
MAILING ADDRESS PO BOX 52110, IRVINE CA 92619-2110			IDENTIFIER: Pool	
TIME IN 12:47 PM			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT 1:41 PM			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
FACILITY ID FA0016070			ACTION: 01 - NO FURTHER ACTION REQUIRED	
RELATED ID PR0021373			PE 3620	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**97**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	240
required flow (gpm)	190
volume (gal)	68,340
area (sq ft)	2,277
occupancy	113

**IMPORTANT: Replacement of Suction Outlet Covers**

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K518 Water Quality – Cyanuric acid concentration**

**POINTS**  
**1**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC - 65530

**Inspector Comments:** Observed cyanuric acid level in pool water too high. Maintain cyanuric acid level at no more than 100 ppm.

**Violation Description:** The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.

**36K548 Equipment - General Requirements - System Description**

**POINTS**  
**1**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - CCR 24 - 3123B.1

**Inspector Comments:** Provide skimmer weir gates for all skimmers. Observed missing.

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The system shall consist of pumps, filters, chemical feeders, skimmers or perimeter overflow systems, valves, pipes, connections, fittings and appurtenances.

**36K556 Equipment – Plumbing labeled**

**POINTS**  
**1**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - CCR 24 - 3120B

**Inspector Comments:** Provide symbols like arrows on recirculation pipes to indicate flow direction. Observed missing.

**Violation Description:** The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME LA FITNESS	DATE 7/13/2015
LOCATION 16289 SIERRA LAKES PKWY, FONTANA, CA 92335	INSPECTOR Isaac Gebreslassie

A handwritten signature in blue ink, appearing to be "Aracely".

NAME: Aracely  
TITLE: front desk

Total # of Images: 0