



**Public Health**  
**Environmental Health Services**

www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>BUDGET LODGE</b>			DATE <b>8/10/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>2/28/2016</b>
LOCATION <b>668 W FAIRWAY DR, SAN BERNARDINO, CA 92408</b>				INSPECTOR <b>Chris Nwadike</b>	
MAILING ADDRESS <b>668 W FAIRWAY DR, SAN BERNARDINO CA 92408</b>				IDENTIFIER: Pool	
TIME IN <b>10:34 AM</b>	TIME OUT <b>11:35 AM</b>	FACILITY ID <b>FA0018442</b>	RELATED ID <b>PR0024495</b>	PE <b>3620</b>	SERVICE: 001 - INSPECTION - ROUTINE RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




**96**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	81.0
observed flow (gpm)	0
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K504 Water Quality – Non-Critical – Disinfectant level low**

POINTS  
**1**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC - 65529

Inspector Comments: Observed chlorine level at 0.73ppm.  
 Maintain between 2.0 and 10.0ppm.

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

**36K518 Water Quality – Cyanuric acid concentration**

POINTS  
**1**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC - 65530

Inspector Comments: Observed cyanuric acid level at 104.00ppm.  
 Maintain below 100.0ppm (under 50.0ppm preferred).

**Violation Description:** The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.



## Public Health

### Environmental Health Services

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME <b>BUDGET LODGE</b>	DATE <b>8/10/2015</b>
LOCATION <b>668 W FAIRWAY DR, SAN BERNARDINO, CA 92408</b>	INSPECTOR <b>Chris Nwadike</b>

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K528 Safety – Safety equipment

**POINTS**  
**1**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC - 65540

**Inspector Comments:** Observed a very short rope attachment to the life ring.  
Provide rope attachment long enough to span the width of the pool.

**Violation Description:** Except for spray grounds without standing water, the pool operator shall ensure that the following safety and first aid equipment is provided and maintained readily visible and available for use at the public pool at all times:

- (1) A 17-inch-minimum (exterior diameter) life ring with an attached throw rope with a minimum 3/16-inch diameter. The throw rope shall be of sufficient length to span the maximum width of the public pool and shall be stored in such a way as to prevent kinking or fouling.
- (2) A 12-foot-minimum fixed-length rescue pole with a permanently attached body hook. For spas, the length of the rescue pole shall be of sufficient length to effectuate rescue.

For public pools that exceed 75 feet in length or 50 feet in width, the pool operator shall provide a rescue pole and a life ring on at least two opposing sides of the public pool at centralized locations.

For public pools with lifeguard personnel on duty, the pool operator of each public pool area shall have the following additional safety equipment:

- (1) A Red Cross 10-Person Industrial First Aid Kit or the equivalent.
- (2) An operating telephone.
- (3) A backboard and head immobilizer.

#### 36K582 Maintenance - Public pool site maintenance

**POINTS**  
**1**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC - 65535

**Inspector Comments:** Observed stuck flow meter.  
Repair or replace.

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

#### Overall Inspection Comments

No summary comments have been made for this inspection.

#### Signature(s) of Acknowledgement

NAME:  
TITLE:

Total # of Images: 0