



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME COMFORT INN & SUITES		REINSPECTION DATE Not Specified	INSPECTOR John Babalola	DATE 7/18/2016
LOCATION 450 N SPERRY DR, COLTON, CA 92324		PERMIT EXPIRATION 5/31/2017	IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 9:39 AM	TIME OUT 10:27 AM	FACILITY ID FA0019492	RELATED ID PR0026641	PE 3620
		RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

86
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	50
required flow (gpm)	80
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K502 Water Quality - Critical – Disinfectant level ⚠️ CRITICAL ⚠️

POINTS 5	Compliance Date: Not Specified	Inspector Comments: Observed the free chlorine level at 0.7 ppm at the time of inspection. Provide at least 2.0 ppm at all times. Note: The pool is hereby ordered closed until the free chlorine level is adjusted.
	Not In Compliance	
	Violation Reference - HSC - 65529	

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

36K506 Water Quality - Critical – Water pH 7.2 to 7.8 ⚠️ CRITICAL ⚠️

POINTS 5	Compliance Date: Not Specified	Inspector Comments: Observed the pH level at 6.4 at the time of inspection. Maintain the pH level between 7.2 and 7.8 at all times. Ideal is 7.4 - 7.6. Note: The pool is hereby ordered closed until the pH level is adjusted. Call (800) 442-2283 for a re-inspection prior to re-opening the pool for use. Closed sign posted.
	Not In Compliance	
	Violation Reference - HSC - 65530	

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.

36K518 Water Quality – Cyanuric acid concentration

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the cyanuric acid level above 100 ppm. Maintain below 100 ppm.
	Not In Compliance	
	Violation Reference - HSC - 65530	

Violation Description: The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME COMFORT INN & SUITES	DATE 7/18/2016
LOCATION 450 N SPERRY DR, COLTON, CA 92324	INSPECTOR John Babalola

36K527 Safety – Safety signs

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Provide the nearest emergency services phone number, the name and the address of the facility at the pool side None observed.
	Not In Compliance	
	Violation Reference - CCR - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

36K576 Maintenance – Operation/Incident records

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Maintain daily records of pH, chlorine, and equipment readings. No daily records observed.
	Not In Compliance	
	Violation Reference - HSC - 65523	

Violation Description: The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

36K582 Maintenance - Public pool site maintenance

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Repair the non-functional skimmers. Secure the unstable hand rail on the deep-end.
	Not In Compliance	
	Violation Reference - HSC - 65535	

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

Overall Inspection Comments

The pool is hereby ordered closed until the pH and chlorine levels are adjusted. Call (800) 442-2283 for a re-inspection prior to re-opening the pool for use. Closed sign posted.

Signature(s) of Acknowledgement

NAME: erika quintero
TITLE: Assistant Manager



Public Health
Environmental Health Services

www.SBCounty.gov
www.SBCounty.gov/dph/dehs

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

<small>FACILITY NAME</small> COMFORT INN & SUITES	<small>DATE</small> 7/18/2016
<small>LOCATION</small> 450 N SPERRY DR, COLTON, CA 92324	<small>INSPECTOR</small> John Babalola

Total # of Images: 0