



**Public Health**  
**Environmental Health Services**



www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME UNIVERSITY PALMS APTS			DATE 7/24/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 4/30/2015
LOCATION 25356 COLE ST, LOMA LINDA, CA 92354				INSPECTOR Veronica Vazquez	
MAILING ADDRESS 1353 RHONDA LN, REDLANDS CA 92373			<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT IDENTIFIER: Pool SERVICE: 008 - INSPECTION - ATTEMPTED RESULT: 00 - NOT APPLICABLE ACTION: 00 - NOT APPLICABLE		
TIME IN 12:13 PM	TIME OUT 12:18 PM	FACILITY ID FA0008687	RELATED ID PR0014101	PE 3620	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	91
volume (gal)	33,000
area (sq ft)	800
occupancy	40

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K996 Attempted Inspection**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed pool closed. Observed deck area broken and pipes exposed.
	Not In Compliance	
	Violation Reference - HSC	

**Description:** An inspection was attempted today. Another inspection will be attempted at a later date.

**36K595 Construction - Construction or alterations**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Submit plans to Division of Environmental Health Services prior to construction of deck area.
	Not In Compliance	
	Violation Reference - CCR - 3103B	

**Violation Description:** A person proposing to construct, renovate or alter a pool, ancillary facilities or equipment and appurtenances shall submit plans and specifications detailing compliance with this chapter to the enforcing agent for review and written approval prior to commencing construction and shall first be cleared by the enforcing agent before substitution if not an exact duplicate of the units being changed or replaced.

**Overall Inspection Comments**

Call Veronica Vazquez at (800) 442-2283 with questions.

**Signature(s) of Acknowledgement**

NAME:  
 TITLE:  
 Total # of Images: 0