



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SHADY TRAILS PARKHOUSE			REINSPECTION DATE Not Specified		INSPECTOR Yanan Zhu	DATE 6/6/2016
LOCATION 15977 PARKSIDE WY, FONTANA, CA 92336			PERMIT EXPIRATION 8/31/2016		IDENTIFIER: Spa	
TIME IN 12:30 PM	TIME OUT 1:28 PM	FACILITY ID FA0024697	RELATED ID PR0032113	PE 3623	SERVICE: 001 - INSPECTION - ROUTINE RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

98
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	101.0
observed flow (gpm)	100
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K995 Permit - Suspension **⚠ CRITICAL ⚠**

POINTS NA	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC	Inspector Comments: Observed free-chlorine residual to be high. The maximum concentration of disinfectant residual shall be 10.0 ppm free chlorine. Maintain free-chlorine level to be at 10 ppm or less. Minimum disinfectant residual shall be at minimum of 1 ppm without cyanuric acid or 2 ppm with cyanuric acid. The health permit to operate is hereby suspended and the spa ordered closed until the listed violation have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office (800) 442-2283 to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.
----------------------------	--	---

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K574 Maintenance – Test kit

POINTS 1	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC - 65529	Inspector Comments: Observed chemical test kit missing. The pool operator shall maintain a test kit for measuring the disinfectant residual, pH, and, if used, cyanuric acid concentration at the public pool. This test kit shall be available for use by the pool operator and the enforcing agent at all times the public pool is in use
---------------------------	--	--

Violation Description: The pool operator shall maintain a test kit for measuring the disinfectant residual, pH, and, if used, cyanuric acid concentration at the public pool. This test kit shall be available for use by the pool operator and the enforcing agent at all times the public pool is in use. The chlorine or bromine test kit shall be the diethyl-p-phenylenediamine (DPD) type or otherwise be capable of testing free-halogen residual.



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SHADY TRAILS PARKHOUSE	DATE 6/6/2016
LOCATION 15977 PARKSIDE WY, FONTANA, CA 92336	INSPECTOR Yanan Zhu

36K584 Maintenance - Operating procedures/Manufacturers' instructions

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed pool operating procedure, and manufacturer's instructions for mechanical and electrical equipment missing. Maintain all documents for review at time of inspection.
	Not In Compliance	
	Violation Reference - HSC - 65521	

Violation Description: The pool operator shall maintain pool operating procedures at the public pool site for use by the pool operator and for inspection by the enforcing agent.
The pool operator shall maintain manufacturers' instructions for the operation and maintenance for all mechanical and electrical equipment and water treatment systems at the public pool site for use by the pool operator and for inspection by the enforcing agent.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

SNA

NAME: signature not available
TITLE:

Total # of Images: 0