



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PACIFIC HIGH SCHOOL		DATE 8/21/2015	REINSPECTION DATE Next Routine	PERMIT EXPIRATION
LOCATION 1020 PACIFIC ST, SAN BERNARDINO, CA 92404			INSPECTOR Chris Nwadike	
MAILING ADDRESS 1020 PACIFIC ST, SAN BERNARDINO, CA 92404			IDENTIFIER: Deep Pool	
TIME IN 2:04 PM			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT 2:42 PM			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
FACILITY ID FA0004188			ACTION: 01 - NO FURTHER ACTION REQUIRED	
RELATED ID PR0013904			PE 3603	

RECREATIONAL HEALTH - Public School Pool / Spa

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




98

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	80.0
observed flow (gpm)	200
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8

POINTS
1

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC - 65530

Inspector Comments: Observed pH level at 7.1
 Maintain pH between 7.2 and 7.8.

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.

36K554 Equipment - Pressure/Vacuum gauge requirements

POINTS
1

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR 24 - 3125B.2

Inspector Comments: Observed no influent gauge.
 Install the influent gauge.

Violation Description: A pressure and vacuum gauge shall be provided for each pump system. Each gauge shall have a scale range approximately 1 ¼ times the maximum anticipated working pressure or vacuum and shall be accurate within 2 percent of scale. The pressure gauge located on the filter shall be marked with the clean start up pressure reading.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
 TITLE:



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PACIFIC HIGH SCHOOL	DATE 8/21/2015
LOCATION 1020 PACIFIC ST, SAN BERNARDINO, CA 92404	INSPECTOR Chris Nwadike

Total # of Images: 0