



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LA FITNESS		REINSPECTION DATE Not Specified		INSPECTOR Isaac Gebreslassie	DATE 10/13/2015
LOCATION 16289 SIERRA LAKES PKWY, FONTANA, CA 92335				PERMIT EXPIRATION 2/28/2016	IDENTIFIER: Pool SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION
TIME IN 3:57 PM	TIME OUT 4:37 PM	FACILITY ID FA0016070	RELATED ID PR0021373	PE 3620	RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	190
volume (gal)	68,340
area (sq ft)	2,277
occupancy	113

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K994 Reinspection

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: Reinspection conducted at this time to determine super chlorination, suggested by our office, following a complaint investigation that a swimmer allegedly had contracted legionnaires disease after having swam in this pool. Upon reinspection, asked manager, Paulene, regarding super chlorination, and tested pool water for chlorine content.
According to the log sheet super chlorination took place on 10/9/15, and chlorine level in pool water measured at 8.0 ppm, while pH level was at 7.6. Water temperature measured at 84 deg F. Pool was kept closed for 3 hours thereafter, according to manager Paulene. Today on testing free chlorine level was at 6.0 ppm.

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: Paulene
TITLE: manager

Total # of Images: 0