



RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

FACILITY NAME YOGURTLAND		REINSPECTION 6/15/2022	INSPECTOR Rubi Guido	DATE 6/1/2022
LOCATION 4235 N UNIVERSITY PKWY 103, SAN BERNARDINO, CA 92407		PERMIT 2/28/2023	IDENTIFIER: None	
TIME IN 4:09 PM	TIME OUT 5:09 PM	FACILITY ID FA0026201	RELATED ID PR0034400	PE 1620
		SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION		
		RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIR		
		ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RETAIL FOOD PROTECTION - Public Eating PI (0-24 Seats)

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice,

See the following pages for the code sections and general requirements that correspond to each violation listed below.

16K995 Permit - Suspension



Compliance Date: Not Specified

Not In Compliance

Violation Reference - HSC

Inspector Comments: The violation(s) observed pose an immediate threat to public health and safety and the health permit to operate is hereby suspended and ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services. The facility is to remain closed until permission is given by Environmental Health Services. Contact Environmental Health Services to schedule a reinspection. A closure sign was posted. Do not remove, relocate, or obstruct the closure sign.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety and the health permit to operate is hereby suspended and ordered closed until the listed violation(s) have been corrected and verified by DEHS. Facility is to remain closed until permission from DEHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. Posted closed, do not move, hide, or remove sign.

16K994 Reinspection

Compliance Date: Not Specified

Not In Compliance

Reference - HSC

Inspector Comments: The purpose of this visit was to conduct a follow-up inspection to verify compliance regarding the employee/customer restroom that was in disrepair.

FINDING(S):

The person in charge stated the following:

- Was informed that the restroom was repaired yesterday, 5/31/22.
- Today, 6/1/22, noticed that the toilet water was rising when it was flushed, so the customers were sent to the Lemonshark Poke facility that is located next door (accessible from inside of Yogurtland).
- There was no sewage backup anywhere in the facility prior to the reinspection.

OBSERVATION(S):

- Upon arrival, the janitorial sink to be half filled with soiled water and paper.
- With water running at all of the sinks in the facility, except for the janitorial sink, the toilet was flushed and sewage backed up into the janitorial sink.
- The janitorial sink to be completely filled with sewage, but not overflowing at this time.
- Overflowing toilet and the water spreading to the customer area and into the back storage/preparation area.
- Water to not be spraying from the valve in the toilet tank at this time.

RESULT(S):

The violation(s) observed pose an immediate threat to public health and safety and the health permit to operate is hereby suspended and ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services. The facility is to remain closed until permission is given by Environmental Health Services. Contact Environmental Health Services to schedule a reinspection. A closure sign was posted. Do not remove, relocate, or obstruct the closure sign.

Description: Reinspection conducted at this time to determine compliance from prior inspection.



RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

FACILITY NAME YOGURLAND	DATE 6/1/2022
LOCATION 4235 N UNIVERSITY PKWY 103, SAN BERNARDINO, CA 92407	INSPECTOR Rubi Guido

16C022 Sewage and wastewater properly disposed

! CRITICAL !

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 114197

Inspector Comments: Observed the following:

- Upon arrival, the janitorial sink to be half filled with soiled water and paper.
- With water running at all of the sinks in the facility, except for the janitorial sink, the toilet was flushed and sewage backed up into the janitorial sink.
- The janitorial sink to be completely filled with sewage, but not overflowing at this time.
- Overflowing toilet and the water spreading to the customer area and into the back storage/preparation area.

All liquid waste must drain to an approved fully functioning sewage disposal system. Toilet facilities must be operable. Ensure to sanitize all affected areas.

The violation(s) observed pose an immediate threat to public health and safety and the health permit to operate is hereby suspended and ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services. The facility is to remain closed until permission is given by Environmental Health Services. Contact Environmental Health Services to schedule a reinspection. A closure sign was posted. Do not remove, relocate, or obstruct the closure sign.

Violation Description: All liquid waste must drain to an approved fully functioning sewage disposal system. (114197) Toilet facilities must be operable.

Overall Inspection Comments

No summary comments have been made for this inspection.

FREE Classes to L.E.A.R.N!

Liaison Education And Risk Network (L.E.A.R.N.) is a FREE class based on the fundamentals of Active Managerial Control and the Centers for Disease Control and Prevention's five risk factors that lead to foodborne illnesses. Find out when the next L.E.A.R.N. class is by checking our [calendar](#).

Signature(s) of Acknowledgement

NO sig

NAME: Alexandra Nevarez
TITLE: Manager

Total # of Images: 0