



**Public Health**  
Environmental Health Services




www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME SYCAMORE RIDGE APARTMENTS		DATE 6/27/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 5/31/2016
LOCATION 2020 N GUTHRIE ST, SAN BERNARDINO, CA 92404			INSPECTOR Sierra Clayborn	
MAILING ADDRESS 2900 ADAMS ST STE C200, RIVERSIDE CA 92504			IDENTIFIER: Spa	
TIME IN 8:44 AM			SERVICE: 037 - POOL/SPA - BILLABLE INSPECTION SERVIC	
TIME OUT 9:02 AM			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
FACILITY ID FA0008885			ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN	
RELATED ID PR0016012			PE 3623	

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	32
volume (gal)	950
area (sq ft)	50
occupancy	5

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K992 Permit Reinstatement**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Spa permit reinstated and area open for use.
	Not In Compliance	
	Violation Reference - HSC	

**Description:** The health permit to operate is hereby reinstated and facility may open.

**36K993 Re-Reinspection**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> During previous re-reinspection, observed spa chlorine exceeding 10ppm.  During today's additional re-reinspection, observed spa free chlorine at 3.5ppm. Maintain spa free chlorine between 3.0ppm and 10ppm.
	Not In Compliance	
	Violation Reference - HSC	

**Description:** Billable re-reinspection conducted at the time to determine compliance from prior inspection.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:  
Total # of Images: 0