



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>HAMPTON INN &amp; SUITES</b>		DATE <b>7/30/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>7/31/2015</b>
LOCATION <b>2710 LENWOOD RD, BARSTOW, CA 92311</b>			INSPECTOR <b>Michelle Saltis</b>	
MAILING ADDRESS <b>1806 E MAIN ST, MESA AZ 85203</b>			IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN <b>2:30 PM</b>	TIME OUT <b>3:10 PM</b>	FACILITY ID <b>FA0015644</b>	RELATED ID <b>PR0020794</b>	PE <b>3620</b>
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 03 - REINSPECTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




**97**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	65
required flow (gpm)	65
volume (gal)	23,350
area (sq ft)	760
occupancy	38

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K518 Water Quality – Cyanuric acid concentration**

<b>POINTS</b> <b>1</b>	Compliance Date: <b>Not Specified</b>	Inspector Comments: <b>Maintain cyanuric acid at or below 100ppm.</b>
	Not In Compliance	Observed cyanuric acid at or above 111ppm in water.
	Violation Reference - <b>HSC - 65530</b>	

**Violation Description:** The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.



## Public Health

### Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME <b>HAMPTON INN &amp; SUITES</b>	DATE <b>7/30/2015</b>
LOCATION <b>2710 LENWOOD RD, BARSTOW, CA 92311</b>	INSPECTOR <b>Michelle Saltis</b>

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K527 Safety – Safety signs

**POINTS**  
**1**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3120B

**Inspector Comments:** Immediately provide the nearest emergency contact center phone number and site location address on safety sign.

Did not observe the nearest emergency contact center phone number and site location address posted on the safety sign.

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

#### 36K542 Enclosure – Non-Critical – Gates and doors self-closing and self-latching

**POINTS**  
**1**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3119B

**Inspector Comments:** Ensure gates self close/latch.

Observed north gate not self closing/latching. A reinspection will be conducted within week to follow up on compliance. Gate was zipped tied shut. Failure to comply may result in a charged reinspection.

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.

#### Overall Inspection Comments

A reinspection will be conducted within week to follow up on compliance. Failure to comply may result in a charged reinspection.

#### Signature(s) of Acknowledgement

NAME: brianne whiting  
TITLE:



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME HAMPTON INN & SUITES	DATE 7/30/2015
LOCATION 2710 LENWOOD RD, BARSTOW, CA 92311	INSPECTOR Michelle Saltis

Total # of Images: 0