



**Public Health**  
Environmental Health Services

www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>GREEN TREE INN &amp; EXTENDED STAY SUITES</b>		DATE <b>6/22/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>2/28/2016</b>
LOCATION <b>14173 GREEN TREE BL, VICTORVILLE, CA 92392</b>			INSPECTOR <b>Patrick Baccari</b>	
MAILING ADDRESS <b>9887 CARMELITA AV, BEVERLY HILLS CA 90210</b>			IDENTIFIER: Spa	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN <b>3:30 PM</b>	TIME OUT <b>4:12 PM</b>	FACILITY ID <b>FA0009178</b>	RELATED ID <b>PR0014142</b>	PE <b>3623</b>
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**100**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	21
volume (gal)	633
area (sq ft)	39
occupancy	4

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:  
1. Meet the latest ANSI/APSP-16 performance standard  
2. Be rated for the maximum designed flow-rate of the pump  
Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**No Violations Cited**

**Overall Inspection Comments**

Spa is secured closed and not open for use, it's in a fully enclosed building. Suggested a drained pool permit. Repairs are needed prior to opening spa for use ( heater).

**Signature(s) of Acknowledgement**

NAME: stan bane  
TITLE:  
Total # of Images: 0