



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>ORCHARD MEADOWS II</b>		REINSPECTION DATE <b>Not Specified</b>	INSPECTOR <b>Ngoc Le</b>	DATE <b>9/16/2016</b>
LOCATION <b>8320 VINEYARD, RANCHO CUCAMONGA, CA 91730</b>		PERMIT EXPIRATION <b>8/31/2017</b>	IDENTIFIER: Front Spa, Knollwood/Applewood	
TIME IN <b>10:36 AM</b>	TIME OUT <b>11:11 AM</b>	FACILITY ID <b>FA0007325</b>	RELATED ID <b>PR0014640</b>	PE <b>3623</b>
		SERVICE: 001 - INSPECTION - ROUTINE		
		RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED		
		ACTION: 01 - NO FURTHER ACTION REQUIRED		

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

**93**  
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	103.1
observed flow (gpm)	35
required flow (gpm)	31
volume (gal)	926
area (sq ft)	64
occupancy	6

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K518 Water Quality – Cyanuric acid concentration**

<b>POINTS</b> <b>1</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Measured cyanuric acid concentration to be above 120.0 ppm.
	<b>Not In Compliance</b>	
	Violation Reference - <b>HSC - 65530</b>	Maintain cyanuric acid below the maximum level of 100.0 ppm.

**Violation Description:** The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.

**36K527 Safety – Safety signs**

<b>POINTS</b> <b>1</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed no phone number of nearest emergency services.
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR - 3120B</b>	Provide a phone number of nearest emergency service other than 911 with text not less than 1 inch.

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""



## RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME ORCHARD MEADOWS II	DATE 9/16/2016
LOCATION 8320 VINEYARD, RANCHO CUCAMONGA, CA 91730	INSPECTOR Ngoc Le

### 36K556 Equipment – Plumbing labeled

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed no labels of valves, plumbing lines and the directional symbols in the equipment area. Operator took corrective action on site.
	Violation Reference - CCR 24 - 3120B	Provide labels for valves, plumbing lines with the directional symbols such as arrows on all piping.

**Violation Description:** The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.

### 36K556 Equipment – Plumbing labeled

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed no labels of valves, plumbing line and the directional symbols in the equipment area. Operator took corrective action on site. pipings are labeled.
	Violation Reference - CCR 24 - 3120B	Maintain labels of valves, plumbing line with the directional symbols such as arrows on all piping.

**Violation Description:** The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.

### 36K560 Equipment – Waste water

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed pipes between pool and spa filters to separation tank are disconnected. Operator took corrective action on site. Pipes are then connected.
	Violation Reference - CCR - 3141B	Continue following up on pipe lines between filter and separation tank to ensure pipings are secured.

**Violation Description:** There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system.

Material cleaned from filters and backwash water from any recirculation system shall be disposed in a manner that is acceptable to the local wastewater agency and will not create a nuisance. Backwash water shall not be returned to a pool. Pipes carrying wastewater from pools including pool drainage and backwash from filters shall be installed as an indirect waste in accordance with the requirements of Chapter 8 of the California Plumbing Code.

The backwash from a diatomaceous earth filter shall discharge into a separation tank that has been installed to collect the waste diatomaceous earth mixture. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

### 36K574 Maintenance – Test kit

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed only able to read up to 5.0 ppm maximum concentration of free-chlorine.
	Violation Reference - HSC - 65529	Provide a test kit that is able to measure the required maximum and minimum of free-chlorine concentration between 3.0 ppm to 10.0 ppm.

**Violation Description:** The pool operator shall maintain a test kit for measuring the disinfectant residual, pH, and, if used, cyanuric acid concentration at the public pool. This test kit shall be available for use by the pool operator and the enforcing agent at all times the public pool is in use. The chlorine or bromine test kit shall be the diethyl-p-phenylenediamine (DPD) type or otherwise be capable of testing free-halogen residual.

### 36K576 Maintenance – Operation/Incident records

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed written record was not recorded daily.
	Violation Reference - HSC - 65523	Maintain a consistent maintenance records of all daily test results including readings, calibrations, and corrective actions taken at the pool site (to include pH, water temperature and disinfectant level).

**Violation Description:** The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

### Overall Inspection Comments

No summary comments have been made for this inspection.



Public Health  
Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)  
[www.SBCounty.gov/dph/dehs](http://www.SBCounty.gov/dph/dehs)

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME ORCHARD MEADOWS II	DATE 9/16/2016
LOCATION 8320 VINEYARD , RANCHO CUCAMONGA, CA 91730	INSPECTOR Ngoc Le

**Signature(s) of Acknowledgement**

NAME:

TITLE:

Total # of Images: 0