



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>LAKE ARROWHEAD RESORT AND SPA</b>		DATE <b>7/6/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>7/31/2015</b>
LOCATION <b>27984 HWY 189 , LAKE ARROWHEAD, CA 92352</b>			INSPECTOR <b>Yvette Velasco</b>	
MAILING ADDRESS <b>PO BOX 1699, LAKE ARROWHEAD CA 92352</b>			IDENTIFIER: Men's Spa	
TIME IN <b>1:15 PM</b>			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT <b>1:45 PM</b>			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
FACILITY ID <b>FA0006884</b>			ACTION: 01 - NO FURTHER ACTION REQUIRED	
RELATED ID <b>PR0013884</b>			PE <b>3623</b>	




**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**96**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	102.0
observed flow (gpm)	55
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K504 Water Quality – Non-Critical – Disinfectant level low**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed the bromine level in the spa at 0.2 ppm.
	Not In Compliance	Ensure to maintain a minimum of 4.0 ppm bromine in the spa.
	Violation Reference - HSC - 65529	

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

**36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed the pH level at 7.0.
	Not In Compliance	Maintain the pH at 7.2-7.8.
	Violation Reference - HSC - 65530	

**Violation Description:** The pool operator shall maintain public pool water at pH 7.2 to 7.8.

**36K556 Equipment – Plumbing labeled**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed no direction of flow labeling on the recirculation equipment.
	Not In Compliance	Ensure to label system with the direction of flow.
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.



## Public Health

### Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME <b>LAKE ARROWHEAD RESORT AND SPA</b>	DATE <b>7/6/2015</b>
LOCATION <b>27984 HWY 189, LAKE ARROWHEAD, CA 92352</b>	INSPECTOR <b>Yvette Velasco</b>

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K560 Equipment – Waste water

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed an insufficient air gap at the backwash drain.
	Not In Compliance	Ensure to maintain a minimum one inch air gap at the backwash drain.
Violation Reference - CCR - 3141B		

**Violation Description:** There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system.

Material cleaned from filters and backwash water from any recirculation system shall be disposed in a manner that is acceptable to the local wastewater agency and will not create a nuisance. Backwash water shall not be returned to a pool. Pipes carrying wastewater from pools including pool drainage and backwash from filters shall be installed as an indirect waste in accordance with the requirements of Chapter 8 of the California Plumbing Code.

The backwash from a diatomaceous earth filter shall discharge into a separation tank that has been installed to collect the waste diatomaceous earth mixture. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

#### Overall Inspection Comments

See pool report for signature.

#### Signature(s) of Acknowledgement

NAME:  
TITLE:

Total # of Images: 0