



**Public Health**  
Environmental Health Services

www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>AMERICAS BEST VALUE INN &amp; SUITES</b>		DATE <b>6/10/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>7/31/2015</b>
LOCATION <b>2425 S ARCHIBALD AV, ONTARIO, CA 91761</b>			INSPECTOR <b>Veronica Martinez</b>	
MAILING ADDRESS <b>2425 S ARCHIBALD AV, ONTARIO, CA 91761</b>			IDENTIFIER: Pool	
			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN <b>9:53 AM</b>	TIME OUT <b>10:53 AM</b>	FACILITY ID <b>FA0004833</b>	RELATED ID <b>PR0013537</b>	PE <b>3620</b>
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**90**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	40
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:  
1. Meet the latest ANSI/APSP-16 performance standard  
2. Be rated for the maximum designed flow-rate of the pump  
Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K502 Water Quality - Critical – Disinfectant level** ⚠ CRITICAL ⚠

<b>POINTS</b> <b>5</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed free chlorine residual measuring above 11.0 ppm. Maintain free chlorine residual between 2.0 ppm and 10.0 ppm in the presence of cyanuric acid. The pool is hereby ordered closed.
	Not In Compliance	
	Violation Reference - HSC - 65529	

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.



## Public Health

### Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME AMERICAS BEST VALUE INN & SUITES	DATE 6/10/2015
LOCATION 2425 S ARCHIBALD AV, ONTARIO, CA 91761	INSPECTOR Veronica Martinez

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K527 Safety – Safety signs

POINTS <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed existing sign stating "children under the age of 16 should not use pool without a parent or adult guardian in attendance" with incorrect verbage. Replace sign with correct verbage "shall" instead of "should" as well as the following missing safety signs: Telephone number to nearest emergency service, name and street address of pool facility. Provide missing information.
	Not In Compliance	
	Violation Reference - CCR - 3120B	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

#### 36K538 Enclosure – Non-Critical – Fencing/Enclosure

POINTS <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed vertical member of fencing unfastened at bottom due to rust next to chair lift. Repair/replace.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

**Violation Description:** The enclosure shall have a minimum effective perpendicular height of 5 feet. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch (102 mm) diameter sphere. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children. Chain link may be used, provided that the openings are not greater than 1 1/4 inches (44 mm) measured horizontally.

#### 36K548 Equipment - General Requirements - System Description

POINTS <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed direct connection between backwash line and recirculation return line. Ensure there is no direct connection from backwash line to pool return line and ensure corrected backwash line has a 1" minimum air gap to sewer.
	Not In Compliance	
	Violation Reference - CCR 24 - 3123B.1	

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The system shall consist of pumps, filters, chemical feeders, skimmers or perimeter overflow systems, valves, pipes, connections, fittings and appurtenances.

#### 36K556 Equipment – Plumbing labeled

POINTS <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed directional arrows indicating flow of recirculation system missing. Provide directional arrows on all recirculation piping.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	Repeat violation.

**Violation Description:** The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.



## Public Health

### Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME AMERICAS BEST VALUE INN & SUITES	DATE 6/10/2015
LOCATION 2425 S ARCHIBALD AV, ONTARIO, CA 91761	INSPECTOR Veronica Martinez

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K576 Maintenance – Operation/Incident records

POINTS <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed daily records unavailable. Provide and maintain
	Not In Compliance Violation Reference - HSC - 65523	

**Violation Description:** The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

#### 36K596 Permit - Public Pool Closure

POINTS <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: The health permit to operate is hereby suspended due to a chlorine level measured above 11.0 ppm. The pool is ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). Contact EHS office at 1(800) 442-2283 to schedule a reinspection to reinstate the health permit.
	Not In Compliance Violation Reference - HSC - 65545	

The facility is to remain closed until permission from Environmental Health Services (EHS) is given. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee of \$240. per hour.

**Description:** A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.

#### Overall Inspection Comments

No summary comments have been made for this inspection.

#### Signature(s) of Acknowledgement

NAME: P. C. Shah  
TITLE: Manager

Total # of Images: 0