



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>VICTORVILLE LAKE VIEW</b>		DATE <b>6/29/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>11/30/2015</b>
LOCATION <b>13547 LAKESIDE DR, VICTORVILLE, CA 92392</b>			INSPECTOR <b>Dawn LaFlower</b>	
MAILING ADDRESS <b>195 N EUCLID AV STE 100, UPLAND CA 91786</b>			IDENTIFIER: Pool	
TIME IN <b>8:14 AM</b>			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT <b>9:19 AM</b>			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQ	
FACILITY ID <b>FA0000037</b>			ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	
RELATED ID <b>PR0016024</b>			PE <b>3620</b>	



**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**91**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

<b>Ideal</b>
<b>In Compliance</b>
<b>Not in Compliance</b>



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	92
volume (gal)	33,127
area (sq ft)	979
occupancy	49

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:  
1. Meet the latest ANSI/APSP-16 performance standard  
2. Be rated for the maximum designed flow-rate of the pump  
Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K995 Permit - Suspension** ⚠ CRITICAL ⚠

<b>POINTS</b> <b>NA</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Health permit suspended due to recirculation system not operating.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K570 Maintenance – Critical – Flow rate/Turnover rate** ⚠ CRITICAL ⚠

<b>POINTS</b> <b>5</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Ensure recirculation system is functioning during operating hours.
	Not In Compliance	
	Violation Reference - CCR - 3124B, 65525	Operating hours posted 8:00 am to 8:00 pm. Observed recirculation system not operating.

**Violation Description:** The recirculation system shall have the capacity to provide a complete turnover of pool water in:

1. One-half hour or less for a spa pool; and
2. One-half hour or less for a spray ground; and
3. One hour or less for a wading pool; and
4. Two hours or less for a medical pool; and
5. Six hours or less for all other types of public pools.

The variation in flow rate of an operating recirculation system shall be such as not to reduce the flow below 75 percent of the rate required in section 3124B, Title 24, California Code of Regulations.



## Public Health

### Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME VICTORVILLE LAKE VIEW	DATE 6/29/2015
LOCATION 13547 LAKESIDE DR, VICTORVILLE, CA 92392	INSPECTOR Dawn LaFlower

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K527 Safety – Safety signs

POINTS <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Provide the following information on safety sign: the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch.  Provide the following sign:  A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
	Not In Compliance	
	Violation Reference - CCR - 3120B	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

#### 36K528 Safety – Safety equipment

POINTS <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Provide rope for life ring.  Observed rope missing.
	Not In Compliance	
	Violation Reference - HSC - 65540	

**Violation Description:** Except for spray grounds without standing water, the pool operator shall ensure that the following safety and first aid equipment is provided and maintained readily visible and available for use at the public pool at all times:

- (1) A 17-inch-minimum (exterior diameter) life ring with an attached throw rope with a minimum 3/16-inch diameter. The throw rope shall be of sufficient length to span the maximum width of the public pool and shall be stored in such a way as to prevent kinking or fouling.
- (2) A 12-foot-minimum fixed-length rescue pole with a permanently attached body hook. For spas, the length of the rescue pole shall be of sufficient length to effectuate rescue.

For public pools that exceed 75 feet in length or 50 feet in width, the pool operator shall provide a rescue pole and a life ring on at least two opposing sides of the public pool at centralized locations.

For public pools with lifeguard personnel on duty, the pool operator of each public pool area shall have the following additional safety equipment:

- (1) A Red Cross 10-Person Industrial First Aid Kit or the equivalent.
- (2) An operating telephone.
- (3) A backboard and head immobilizer.



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>VICTORVILLE LAKE VIEW</b>	DATE <b>6/29/2015</b>
LOCATION <b>13547 LAKESIDE DR, VICTORVILLE, CA 92392</b>	INSPECTOR <b>Dawn LaFlower</b>

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K556 Equipment – Plumbing labeled**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Clearly label the direction of flow on recirculation pipes.
	Not In Compliance Violation Reference - CCR 24 - 3120B	Observed pipes not labeled.

**Violation Description:** The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.

**36K587 Ancillary - Drinking Fountains Required**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Repair drinking fountain.
	Not In Compliance Violation Reference - CCR 24 - 3117B	Observed not functioning.

**Violation Description:** One guarded jet drinking fountain shall be provided for the first 250 pool users and an additional fountain shall be provided for each additional 200 pool users or fraction thereof.

**Overall Inspection Comments**

Health permit suspended due to recirculation system not functioning during operating hours. Notice of Closure sign posted. Do not remove sign or reopen pool without a reinspection and approval from Environmental Health.

Contact Environmental Health at 800-442-2283 for a reinspection. Recirculation system must be operating during operating hours.

Please provide keys to pump enclosure to Environmental Health.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0