



**RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>JUICE IT UP!</b>		DATE <b>9/3/2015</b>	REINSPECTION DATE <b>9/17/2015</b>	PERMIT EXPIRATION <b>8/31/2015</b>
LOCATION <b>8678 19TH ST 110, RANCHO CUCAMONGA, CA 91701</b>			INSPECTOR <b>Dior Porter</b>	
MAILING ADDRESS <b>2422 ELIZABETH CT, UPLAND CA 91784</b>			IDENTIFIER: None	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN <b>1:30 PM</b>	TIME OUT <b>2:03 PM</b>	FACILITY ID <b>FA0015651</b>	RELATED ID <b>PR0020805</b>	PE <b>1620</b>
RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU				
ACTION: 03 - REINSPECTION REQUIRED				

**RETAIL FOOD PROTECTION - Public Eating PI (0-24 Seats)**

**No Violations Cited**

**Overall Inspection Comments**

Reinspection to determine compliance for hot water. Measured water of 120 F at the 3 compartment sink however, hot water turned off at food preparation sink. Observed leak at the faucet of the 3 compartment sink. Eliminate the leak and maintain the plumbing in good condition. Observed lack of warm water at the restroom sink. Provide warm water at a minimum of 100F. Maintain all hot and cold water faucets on during operational hours. Will return for a billable reinspection to determine compliance within 24 hours. Failure to comply may result in closure, legal action and billable re-inspections.

**Signature(s) of Acknowledgement**

NAME: Natalie Espinosa  
TITLE:

Total # of Images: 0