



Public Health
Environmental Health Services

www.SBCounty.gov
www.SBCounty.gov/dph/dehs

RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

| | | | | | |
|--|---------------------|--------------------------|------------------------------------|--------------------------------|--|
| FACILITY NAME MOUNTAIN SPRINGS | | | REINSPECTION DATE Not Specified | INSPECTOR Bennetta Betbadal | DATE 11/5/2015 |
| LOCATION 1413 SAN BERNARDINO RD, UPLAND, CA 91768 | | | PERMIT EXPIRATION | IDENTIFIER: None | |
| TIME IN 9:40 AM | TIME OUT 9:50 AM | FACILITY ID FA0006123 | RELATED ID SR0069657 | PE 3755 | SERVICE: 126 - PLAN CHECK FIELD INSPECTION RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED ACTION: 01 - NO FURTHER ACTION REQUIRED |

RECREATIONAL HEALTH PLAN CHECK - Plan Check Rec Health Consultation

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

37K509 Plans - Final Inspection

Compliance Date: Not Specified

Inspector Comments: Final inspection for SVRS pump added for the pool. Observed flow rate at 50 gpm.

Not In Compliance

Reference - Reference Number - SBC Policy

Description: Final inspection hereby gives facility approvals to open.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:

TITLE:

Total # of Images: 0