



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

|  |                      |                          |                         |                                     |  |
|--|----------------------|--------------------------|-------------------------|-------------------------------------|--|
| FACILITY NAME<br>SAN BERNARDINO HIGH SCHOOL  |                      |                          | DATE<br>8/21/2015       | REINSPECTION DATE<br>Next Routine   | PERMIT EXPIRATION                                |
| LOCATION<br>1850 N E ST, SAN BERNARDINO, CA 92405  |                      |                          |                         | INSPECTOR<br>Chris Nwadike          |  |
| MAILING ADDRESS<br>1850 N E ST, SAN BERNARDINO, CA 92405   |                      |                          |                         | IDENTIFIER: Deep Pool               |  |
| <input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT |                      |                          |                         | SERVICE: 001 - INSPECTION - ROUTINE |  |
| TIME IN<br>10:39 AM  | TIME OUT<br>11:36 AM | FACILITY ID<br>FA0006490 | RELATED ID<br>PR0014841 | PE<br>3603                          | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE |
|  |                      |                          |                         |                                     | ACTION: 01 - NO FURTHER ACTION REQUIRED          |

**RECREATIONAL HEALTH - Public School Pool / Spa**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




**99**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

|                   |
|-------------------|
| Ideal             |
| In Compliance     |
| Not in Compliance |



|                     |         |
|---------------------|---------|
| temperature (°F)    | 82.0    |
| observed flow (gpm) | 250     |
| required flow (gpm) | No Data |
| volume (gal)        | No Data |
| area (sq ft)        | No Data |
| occupancy           | No Data |

**IMPORTANT: Replacement of Suction Outlet Covers**

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K504 Water Quality – Non-Critical – Disinfectant level low**

**POINTS**  
**1**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC - 65529

Inspector Comments: Observed chlorine level at 1.40ppm. Maintain between 2.0 and 10.0ppm.

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0