



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PARK VISTA		REINSPECTION DATE Not Specified		INSPECTOR Veronica Martinez	DATE 9/21/2015
LOCATION 1031 S PALMETTO, ONTARIO, CA 91761				PERMIT EXPIRATION 2/28/2016	IDENTIFIER: Lone Spa
TIME IN 12:45 PM	TIME OUT 1:26 PM	FACILITY ID FA0008422	RELATED ID PR0013982	PE 3623	SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).




92

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	100.8
observed flow (gpm)	80
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K502 Water Quality - Critical – Disinfectant level **⚠ CRITICAL ⚠**

POINTS 5	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine measuring above 11.0 ppm.
	Not In Compliance	
	Violation Reference - HSC - 65529	Maintain free chlorine between 3.0 ppm and 10.0 ppm.

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

36K556 Equipment – Plumbing labeled

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed directional symbols indicating flow and recirculation equipment unlabeled.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	Label.

Violation Description: The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PARK VISTA	DATE 9/21/2015
LOCATION 1031 S PALMETTO , ONTARIO, CA 91761	INSPECTOR Veronica Martinez

36K572 Maintenance – Pool shell cleanliness; slime and algae

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed shell heavily etched, with slight algae growth on walls. Clean and maintain.
	Not In Compliance	
	Violation Reference - HSC - 65533	

Violation Description: (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash, or leaves, to accumulate in the public pool. The pool operator shall ensure that water levels are maintained and operated to remove such material continuously through the pool skimming system in accordance with section 3136B, Title 24, California Code of Regulations.

(b) The pool operator shall clean the bottom, sides, and other surfaces of the public pool as often as necessary to keep the bottom, sides, and public pool surfaces clean and free of slime and algae.

36K582 Maintenance - Public pool site maintenance

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed broken glass on deck next to safety signs. Remove and maintain free of hazardous objects. Correction: Broken glass removed and discarded. Observed heavy accumulation of leaves in equipment area. Clean and maintain.
	Not In Compliance	
	Violation Reference - HSC - 65535	

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

36K596 Permit - Public Pool Closure

POINTS NA	Compliance Date: Not Specified	Inspector Comments: The spa is hereby ordered closed due to a high free chlorine level measured above 11.0 ppm. Contact Division of Environmental Health Services (DEHS) at 1(800) 442-2283 to request a re-inspection to open pool. Do not open pool for use unless authorized by DEHS. Non-compliance may result in future charged inspection at \$245.00 per hour.
	Not In Compliance	
	Violation Reference - HSC - 65545	

Description: A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.

Overall Inspection Comments

Spa posted closed.

Contact Division of Environmental Health Services (DEHS) at 1(800) 442-2283 to request a re-inspection to open pool. Do not open pool for use unless authorized by DEHS. Non-compliance may result in future charged inspection at \$245.00 per hour.

Signature(s) of Acknowledgement

NAME: Signature not available
TITLE:

Total # of Images: 0