



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME VILLAGE ON THE GREEN APARTMENTS		DATE 6/9/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 9400 FAIRWAY VIEW PL, RANCHO CUCAMONGA, CA 91730			INSPECTOR Nick Thalasinios	
MAILING ADDRESS 9400 FAIRWAY VIEW PL, RANCHO CUCAMONGA CA 91730			IDENTIFIER: Spa	
TIME IN 4:30 PM	TIME OUT 5:50 PM	FACILITY ID FA0014399	RELATED ID PR0028240	PE 3623
			SERVICE: 001 - INSPECTION - ROUTINE	
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	100.5
observed flow (gpm)	45
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K540 Enclosure – Critical – Gates and doors self-closing and self-latching ⚠ CRITICAL ⚠

POINTS 5	Compliance Date: Not Specified	Inspector Comments: Observed a gate does not latch; Gates and doors shall be equipped with self-closing and self-latching devices. Chained shut.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.

36K518 Water Quality – Cyanuric acid concentration

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the cyanuric acid level is greater than 100 ppm; The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.
	Not In Compliance	
	Violation Reference - HSC - 65530	

Violation Description: The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME VILLAGE ON THE GREEN APARTMENTS	DATE 6/9/2015
LOCATION 9400 FAIRWAY VIEW PL, RANCHO CUCAMONGA, CA 91730	INSPECTOR Nick Thalasinios

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K527 Safety – Safety signs

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the signage is incomplete, the club house doors are missing the diarrhea and ""KEEP GATE CLOSED"" warning signs; Signage shall meet all requirements of Title 24, section 3120B, as listed below.
	Not In Compliance	
	Violation Reference - CCR - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

36K597 Construction - Pool shell tiles and surface

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the spa pool shell is stained, peeling; The finished spa pool shell shall be lined with a smooth waterproof interior finish of approved white plaster that will withstand repeated brushing, scrubbing and cleaning procedures. The interior pool finish shall completely line the pool to the tile lines, coping, or cantilevered deck.
	Not In Compliance	
	Violation Reference - CCR - 3108B	

Violation Description: The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing and cleaning procedures. The interior pool finish shall completely line the pool to the tile lines, coping, or cantilevered deck.

The finish color shall be white except for the following which shall be of contrasting color:

1. Lane and other required pool markings described in Section 3110B of the California Code of Regulations; and
2. The top surface edges of benches in spa pools; and
3. The edge of pool steps; and
4. Tiles installed at the waterline; and
5. Tiles installed at the 4 1/2-foot (1372 mm) depth line.

Overall Inspection Comments

Spa

Signature(s) of Acknowledgement

NAME:
TITLE:



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME VILLAGE ON THE GREEN APARTMENTS	DATE 6/9/2015
LOCATION 9400 FAIRWAY VIEW PL, RANCHO CUCAMONGA, CA 91730	INSPECTOR Nick Thalasin

Total # of Images: 0