



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>CAMP NAWAKWA</b>		DATE <b>9/8/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>12/31/2015</b>
LOCATION <b>4650 JENKS LAKE RD, ANGELUS OAKS, CA 92305</b>			INSPECTOR <b>Yvette Velasco</b>	
MAILING ADDRESS <b>1226 N CAMPUS AV, UPLAND CA 91786</b>			IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN <b>12:54 PM</b>	TIME OUT <b>1:20 PM</b>	FACILITY ID <b>FA0006914</b>	RELATED ID <b>PR0006549</b>	PE <b>3620</b>
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 13 - PERMIT SUSPENDE / FACILITY CLOSED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




**92**

**SCORE**

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	66.0
observed flow (gpm)	No Data
required flow (gpm)	190
volume (gal)	87,000
area (sq ft)	1,800
occupancy	90

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K524 Safety – Critical – Electrical hazards; GFCI** **⚠ CRITICAL ⚠**

<b>POINTS</b> <b>5</b>	Compliance Date: Not Specified	Inspector Comments: Observed the GFCI non-functional.
	Not In Compliance	
	Violation Reference - HSC - 116049	Ensure to repair the GFCI as soon as possible.

**Violation Description:** The design and installation of all underwater lighting systems, operating at more than 15 volts, supplied from a branch circuit either directly or by way of a transformer, shall be installed in a public swimming pool so that there is no shock hazard with any likely combination of fault conditions during normal use, and shall comply with both of the following requirements:

- An approved ground-fault circuit interrupter shall be installed in the branch circuit that supplies all fixtures operating at more than 15 volts.
- Only approved underwater lighting fixtures shall be used and no lighting fixtures shall be installed for operations at more than 150 volts between conductors.



## RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME <b>CAMP NAWAKWA</b>	DATE <b>9/8/2015</b>
LOCATION <b>4650 JENKS LAKE RD, ANGELUS OAKS, CA 92305</b>	INSPECTOR <b>Yvette Velasco</b>

### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

### 36K527 Safety – Safety signs

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed the following signs not provided: (B) No diving (H) Keep gate closed (I) Diarrhea
	Not In Compliance Violation Reference - CCR - 3120B	

Ensure to provide all appropriate signs in the pool area.

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

### 36K546 Equipment – Non-Critical - Water treatment system operation

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed the flow meter stuck.  Ensure to repair or replace the flow meter.
	Not In Compliance Violation Reference - HSC - 65525	

**Violation Description:** The pool operator shall operate pumps, filters, disinfectant and chemical feeders, flow indicators, gauges, recirculation systems, disinfection systems, and all parts of the water treatment system whenever the public pool is available for use, and at such additional times and periods as may be necessary to maintain clean pool water, clear pool water, and the disinfection standards required in section 65529 [Health and Safety Code].

### 36K572 Maintenance – Pool shell cleanliness; slime and algae

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed build-up on the pool shell.  Ensure to clean and maintain the pool shell.
	Not In Compliance Violation Reference - HSC - 65533	

**Violation Description:** (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash, or leaves, to accumulate in the public pool. The pool operator shall ensure that water levels are maintained and operated to remove such material continuously through the pool skimming system in accordance with section 3136B, Title 24, California Code of Regulations.

(b) The pool operator shall clean the bottom, sides, and other surfaces of the public pool as often as necessary to keep the bottom, sides, and public pool surfaces clean and free of slime and algae.



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>CAMP NAWAKWA</b>	DATE <b>9/8/2015</b>
LOCATION <b>4650 JENKS LAKE RD, ANGELUS OAKS, CA 92305</b>	INSPECTOR <b>Yvette Velasco</b>

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K596 Permit - Public Pool Closure**

<b>POINTS</b> <b>NA</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Due to the electrical hazard of the GFCI the pool is closed at this time.
	<b>Not In Compliance</b>	
	Violation Reference - <b>HSC - 65545</b>	Inspector will follow up within 14 days. Contact the Division of Environmental Health once the pool is ready to reopen.

**Description:** A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0