



RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

FACILITY NAME RALPHS #113		REINSPECTION DATE 10/23/2015	INSPECTOR Bennetta Betbadal	DATE 10/23/2015
LOCATION 16225 SIERRA LAKES PKWY, FONTANA, CA 92336		PERMIT EXPIRATION	IDENTIFIER: None	
TIME IN 1:00 PM	TIME OUT 2:00 PM	FACILITY ID FA0015030	RELATED ID SR0070592	PE 1779
		SERVICE: 025 - PLAN REVIEW		
		RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED		
		ACTION: 55 - PLANS APPROVED		

RETAIL FOOD PLAN CHECK - Plnck FHP Minor 0-2,499 SqFt

17K986 Plans - Plan Review Approved

Compliance Date: Not Specified
Not In Compliance
Reference - HSC - 114380

Inspector Comments: Plan is approved for minor remodel of the bakery section. Scope of work consist of replacing and relocating some existing equipment. New equipment consist of: Baxter double rack oven, Baxter double door 40" deep proofer, service bakery cases and hand washing sink.

Description: Thank you for your plan submittal.Plans have been approved with the following corrections.This approval does not constitute authority to violate any provision of the related codes, ordinances, or regulations, nor does it prevent further correction of errors found on the plan or with installation upon field inspection. All construction must conform to these approved plans. Alterations or changes to these plans must have review and written approval by the Plan Check Section of Environmental Health Services prior to construction.

17K244 Plans - Submittal - Remodel - Equipment

Compliance Date: Not Specified
Not In Compliance
Reference - HSC - 114130

Inspector Comments:

Description: All new and used food service equipment is subject to final approval by this Agency, as determined at the time of the field inspections.

17K246 Plans - Submittal - Remodel - Final

Compliance Date: Not Specified
Not In Compliance
Reference - Reference Number - SBC Policy

Inspector Comments: Call for final inspection one week in advance.

Description: Final construction must be approved by this Department prior to putting the remodeled areas into operation.

17K247 Plans - Submittal - Remodel - Finishes

Compliance Date: Not Specified
Not In Compliance
Reference - HSC - 114380

Inspector Comments:

Description: Existing finishes are subject to evaluation by this Department. This determination will be made at the time of the preliminary field inspection. Finishes found not to be in compliance with current code requirements will not be accepted.

17K842 Plans - Submittal - Remodel - Protection

Compliance Date: Not Specified
Not In Compliance
Reference - HSC - 113980

Inspector Comments: Strict protective measures must be taken to prevent the contamination of food or food contact surfaces during the course of remodeling. Failure to do so may result in the closure of the food facility until all remodeling activities have been completed.

Description: Strict protective measures must be taken to prevent the contamination of food or food contact surfaces during the course of remodeling. Failure to do so may result in the closure of the food facility until all remodeling activities have been completed.

17K891 Ventilation - Walls

Compliance Date: Not Specified
Not In Compliance
Reference - CCDEH Guidelines - CCDEH

Inspector Comments: Hood shall be flashed/trimmed to the ceiling and adjacent walls. The flashing/trim shall be constructed of the same material and thickness as the hood.

Description: Canopy type hoods shall be flashed/trimmed to the ceiling and adjacent walls. The flashing/trim shall be constructed of the same material and thickness as the hood.

Overall Inspection Comments

No summary comments have been made for this inspection.



RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

FACILITY NAME RALPHS #113	DATE 10/23/2015
LOCATION 16225 SIERRA LAKES PKWY, FONTANA, CA 92336	INSPECTOR Bennetta Betbadal

Signature(s) of Acknowledgement

NAME:

TITLE:

Total # of Images: 0