



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | | | | |
|---|----------------------------|---------------------------------|---|--|
| FACILITY NAME RODEWAY INN | | DATE 8/4/2015 | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 11/30/2015 |
| LOCATION 607 W 5TH ST, SAN BERNARDINO, CA 92410 | | | INSPECTOR Chris Nwadike | |
| MAILING ADDRESS 607 W 5TH ST, SAN BERNARDINO CA 92410 | | | IDENTIFIER: Pool | |
| TIME IN 4:49 PM | TIME OUT 5:31 PM | FACILITY ID FA0013374 | RELATED ID PR0017710 | PE 3620 |
| | | | SERVICE: 001 - INSPECTION - ROUTINE | |
| | | | RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU | |
| | | | ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED | |

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.



91

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (°F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K514 Water Quality – Critical – Water clarity **⚠ CRITICAL ⚠**

POINTS
5

Compliance Date: **Not Specified**
 Not In Compliance
 Violation Reference - HSC - 65527

Inspector Comments: Observed cloudy pool water. The main drain was not visible from the deck. The pool water must be kept clean and clear. The main drain must be clearly visible from the deck. Pool is therefore closed and permit suspended until the water clarity is restored. Call EHS (Chris) at 800-442-2283 for reopening.

Violation Description: The pool operator shall maintain clear pool water while the public pool is in use. The pool operator shall close the public pool if the bottom of the pool at the maximum depth is not clearly visible from the deck. The pool operator shall not reopen the public pool for use until the pool water is clean and clear, and the bottom of the pool at the maximum depth is clearly visible from the deck. If the bottom of the pool is not visible 48 hours following inspection and closure by the enforcing agent, the enforcing agent may order the pool drained.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|---|-----------------------------------|
| FACILITY NAME RODEWAY INN | DATE 8/4/2015 |
| LOCATION 607 W 5TH ST, SAN BERNARDINO, CA 92410 | INSPECTOR Chris Nwadike |

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K527 Safety – Safety signs

| | | |
|---------------------------|--|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: The occupancy load of the pool was not posted. Post the number. |
| | Not In Compliance | |
| | Violation Reference - CCR - 3120B | |

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- A warning sign for spa pools with ""CAUTION"" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

36K528 Safety – Safety equipment

| | | |
|---------------------------|--|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed no rope attachment to the life ring. Provide the rope attachment long enough to span the width of the pool. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65540 | |

Violation Description: Except for spray grounds without standing water, the pool operator shall ensure that the following safety and first aid equipment is provided and maintained readily visible and available for use at the public pool at all times:

- (1) A 17-inch-minimum (exterior diameter) life ring with an attached throw rope with a minimum 3/16-inch diameter. The throw rope shall be of sufficient length to span the maximum width of the public pool and shall be stored in such a way as to prevent kinking or fouling.
- (2) A 12-foot-minimum fixed-length rescue pole with a permanently attached body hook. For spas, the length of the rescue pole shall be of sufficient length to effectuate rescue.

For public pools that exceed 75 feet in length or 50 feet in width, the pool operator shall provide a rescue pole and a life ring on at least two opposing sides of the public pool at centralized locations.

For public pools with lifeguard personnel on duty, the pool operator of each public pool area shall have the following additional safety equipment:

- (1) A Red Cross 10-Person Industrial First Aid Kit or the equivalent.
- (2) An operating telephone.
- (3) A backboard and head immobilizer.

36K556 Equipment – Plumbing labeled

| | | |
|---------------------------|---|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed no labels/markings on the piping in the equipment/pump area showing the direction of water flow/recirculation. The direction of water flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. |
| | Not In Compliance | |
| | Violation Reference - CCR 24 - 3120B | |

Violation Description: The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|---|-----------------------------------|
| FACILITY NAME RODEWAY INN | DATE 8/4/2015 |
| LOCATION 607 W 5TH ST, SAN BERNARDINO, CA 92410 | INSPECTOR Chris Nwadike |

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K582 Maintenance - Public pool site maintenance

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed stuck flow meter. |
| | Not In Compliance | Repair or replace. |
| | Violation Reference - HSC - 65535 | |

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0