



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME AMLI @ VICTORIA ARBORS		DATE 5/20/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 11/30/2015
LOCATION 7922 DAY CREEK BL, RANCHO CUCAMONGA, CA 91739		INSPECTOR Nick Thalasinis		
MAILING ADDRESS 7922 DAY CREEK BL, RANCHO CUCAMONGA CA 91739		IDENTIFIER: Spa		
TIME IN 11:30 AM	TIME OUT 12:30 PM	FACILITY ID FA0014465	RELATED ID PR0019114	PE 3623
		SERVICE: 001 - INSPECTION - ROUTINE RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED		



**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**87**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	101.3
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K506 Water Quality - Critical – Water pH 7.2 to 7.8**



<b>POINTS</b> <b>5</b>	Compliance Date: Not Specified	Inspector Comments: Observed the pH is greater than 8.0; The pool operator shall maintain public pool water at pH 7.2 to 7.8.
	Not In Compliance	
	Violation Reference - HSC - 65530	Corrected during inspection.

**Violation Description:** The pool operator shall maintain public pool water at pH 7.2 to 7.8.

**36K540 Enclosure – Critical – Gates and doors self-closing and self-latching**



<b>POINTS</b> <b>5</b>	Compliance Date: Not Specified	Inspector Comments: Observed the West gate was stuck open; Gates and doors shall be equipped with self-closing and self-latching devices.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.

**36K504 Water Quality – Non-Critical – Disinfectant level low**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed less than 3.0 ppm of free chlorine; The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine.
	Not In Compliance	
	Violation Reference - HSC - 65529	

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME AMLI @ VICTORIA ARBORS	DATE 5/20/2015
LOCATION 7922 DAY CREEK BL, RANCHO CUCAMONGA, CA 91739	INSPECTOR Nick Thalasinios

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K582 Maintenance - Public pool site maintenance**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed the flow meter is not operational; The pool operator shall keep all parts of the public pool site well-maintained.
	Not In Compliance	
	Violation Reference - HSC - 65535	

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

**36K584 Maintenance - Operating procedures/Manufacturers' instructions**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed the operating procedures, manufacturers instructions and equipment manuals are not available on site; Maintain all pool operating procedures, manufacturers' instructions for the operation and maintenance for all mechanical and electrical equipment and water treatment systems at the public pool site for use by the pool operator and for inspection by the enforcing agent.
	Not In Compliance	
	Violation Reference - HSC - 65521	

**Violation Description:** The pool operator shall maintain pool operating procedures at the public pool site for use by the pool operator and for inspection by the enforcing agent.  
 The pool operator shall maintain manufacturers' instructions for the operation and maintenance for all mechanical and electrical equipment and water treatment systems at the public pool site for use by the pool operator and for inspection by the enforcing agent.

**Overall Inspection Comments**

Spa

**Signature(s) of Acknowledgement**

NAME:  
 TITLE:

Total # of Images: 0