



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME COUNTRY INN & SUITES		DATE 6/3/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 11/30/2015
LOCATION 4674 E ONTARIO MILLS PKWY, ONTARIO, CA 91761			INSPECTOR Shannon Johnson	
MAILING ADDRESS 4674 E ONTARIO MILLS PKWY, ONTARIO CA 91764			IDENTIFIER: Spa	
			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 10:40 AM	TIME OUT 11:13 AM	FACILITY ID FA0016685	RELATED ID PR0022270	PE 3623
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

97

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	101.0
observed flow (gpm)	70
required flow (gpm)	43
volume (gal)	1,312
area (sq ft)	70
occupancy	7

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K504 Water Quality – Non-Critical – Disinfectant level low

POINTS
1

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 65529

Inspector Comments: Observed the measured reading for free chlorine within this spa to be 0.64 with cyanuric acid.

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

36K516 Water Quality – Non-Critical – Water clarity

POINTS
1

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 65527

Inspector Comments: Observed the water to be tinted green within the spa. The main drain was clearly visible at this time.

Violation Description: The pool operator shall maintain clear pool water while the public pool is in use. The pool operator shall close the public pool if the bottom of the pool at the maximum depth is not clearly visible from the deck. The pool operator shall not reopen the public pool for use until the pool water is clean and clear, and the bottom of the pool at the maximum depth is clearly visible from the deck. If the bottom of the pool is not visible 48 hours following inspection and closure by the enforcing agent, the enforcing agent may order the pool drained.

36K576 Maintenance – Operation/Incident records

POINTS
1

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 65523

Inspector Comments: Observed no measure reading of cyanuric acid on the daily records. Provide at least once a month.

Violation Description: The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

Overall Inspection Comments



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME COUNTRY INN & SUITES	DATE 6/3/2015
LOCATION 4674 E ONTARIO MILLS PKWY, ONTARIO, CA 91761	INSPECTOR Shannon Johnson

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NSC

NAME:
TITLE:

Total # of Images: 0