



**Public Health**  
**Environmental Health Services**



www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME BRIGHTON AT TERRA VISTA HOA			DATE 7/15/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 2/28/2016
LOCATION 11450 CHURCH ST, RANCHO CUCAMONGA, CA 91730				INSPECTOR Dior Porter	
MAILING ADDRESS 195 N EUCLID AV, UPLAND CA 91785			<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT IDENTIFIER: Spa SERVICE: 008 - INSPECTION - ATTEMPTED RESULT: 00 - NOT APPLICABLE ACTION: 00 - NOT APPLICABLE		
TIME IN 10:41 AM	TIME OUT 10:47 AM	FACILITY ID FA0014424	RELATED ID PR0019058	PE 3623	

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	6

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K996 Attempted Inspection**

**POINTS**  
**NA**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC

**Inspector Comments:** Maintenance personnel was working on fence and gate.

**Description:** An inspection was attempted today. Another inspection will be attempted at a later date.

**Overall Inspection Comments**

Maintenance personnel was working on fence and gate.

**Signature(s) of Acknowledgement**

NAME:  
 TITLE:  
 Total # of Images: 0