



Public Health
Environmental Health Services

www.SBCounty.gov

RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

FACILITY NAME EL TORITO RESTAURANT		DATE 3/23/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION
LOCATION 335 S MOUNTAIN AV, UPLAND, CA 91786			INSPECTOR Nicole Walker	
MAILING ADDRESS 335 S MOUNTAIN AV, UPLAND, CA 91786			IDENTIFIER: None	
			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 3:10 PM	TIME OUT 4:15 PM	FACILITY ID FA0009961	RELATED ID CO0050237	PE 1622
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	

RETAIL FOOD PROTECTION - Public Eating PI (100-Up Seats)

No Violations Cited

Overall Inspection Comments

This is a fire/health permit investigation. Per complaint, El Torito, suffered a stove fire which caused the sprinkler system to be activated 3/19/15.

Observed at time of inspection:

Cook line lined.

Observed filter/vents operating at time of inspection.

Observed stainless steel panels replaced at cook line back splash.

Observed cook line equipment cold holding drawers resting at 50F. (Must hold at 41F).

Observed ansel system recharged per El Torito management.

Observed cook line equipment cleaned. Ensure all cook line equipment is functioning properly.

Observed impacted areas cleaned.(NOTE: Impacted trash thrown in trash at day of fire).

Observed walk in cooler functioning.

At time of inspection, the Upland Fire Department and Ansel provider had not completed system testing.

A re-opening can not be granted by the Health Department until Fire Department has provided certification of El Torito's fire/ansel system.

After hour phone number provided.

El Torito shall not re open at this time. Contact after hour staff if necessary.

Contact Health Department 3/24/15 for re inspection when Fire Certification has been granted.

Ensure cook line is cleaned and in good working order for re-opening.

Signature(s) of Acknowledgement

NAME:

TITLE:

Photo Attachments:

No Photo Attachments