



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME WOODLANDS HOA		DATE 7/1/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 1965 E COULSTON ST, LOMA LINDA, CA 92354			INSPECTOR Veronica Vazquez	
MAILING ADDRESS 12345 MOUNTAIN AV STE N-239, CHINO CA 91710		<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT IDENTIFIER: Spa SERVICE: 001 - INSPECTION - ROUTINE RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		
TIME IN 4:40 PM	TIME OUT 5:00 PM	FACILITY ID FA0008320	RELATED ID PR0014112	PE 3623

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

90

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	104.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	7

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K502 Water Quality - Critical – Disinfectant level ⚠ CRITICAL ⚠

POINTS	Comply by: 7/2/2015	Inspector Comments: Observed free chlorine above 10 ppm in spa water. Maintain free chlorine between 3-10 ppm.
5	Not In Compliance	Repeat violation.
	Violation Reference - HSC - 65529	

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

36K522 Safety – Critical – Unsafe or hazardous conditions ⚠ CRITICAL ⚠

POINTS	Compliance Date: Not Specified	Inspector Comments: Spa is hereby closed due to high free chlorine above 10 ppm. Posted closure sign.
5	Not In Compliance	Contact the County of San Bernardino, Division of Environmental Health Services (DEHS) when compliance is reached. Maintain spa closed until re-opened by DEHS inspector.
	Violation Reference - HSC - 65545	

Violation Description: A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent.

Overall Inspection Comments

Verify spa light is in good repair. Unable to access equipment room. Provide key to equipment room.

Call Veronica Vazquez at (800) 442-2283 with questions.

Signature(s) of Acknowledgement



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME WOODLANDS HOA	DATE 7/1/2015
LOCATION 1965 E COULSTON ST, LOMA LINDA, CA 92354	INSPECTOR Veronica Vazquez

NAME:
TITLE:

Total # of Images: 0