



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LA FITNESS			DATE 8/10/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 9/30/2015
LOCATION 14485 PIPELINE AV, CHINO HILLS, CA 91709				INSPECTOR Casey Salazar	
MAILING ADDRESS PO BOX 52110, IRVINE CA 92619				IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 12:20 PM	TIME OUT 12:50 PM	FACILITY ID FA0000838	RELATED ID PR0015845	PE 3620	RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.


98

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	95
required flow (gpm)	151
volume (gal)	54,400
area (sq ft)	1,849
occupancy	92

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K560 Equipment – Waste water

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed air gap missing from wastewater discharge line. Ensure all draining pipes are separated from drainage system by a 1 inch air gap.
	Not In Compliance	
	Violation Reference - CCR - 3141B	

Violation Description: There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system.

Material cleaned from filters and backwash water from any recirculation system shall be disposed in a manner that is acceptable to the local wastewater agency and will not create a nuisance. Backwash water shall not be returned to a pool. Pipes carrying wastewater from pools including pool drainage and backwash from filters shall be installed as an indirect waste in accordance with the requirements of Chapter 8 of the California Plumbing Code.

The backwash from a diatomaceous earth filter shall discharge into a separation tank that has been installed to collect the waste diatomaceous earth mixture. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

36K562 Skimmers - Pool skimming systems

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed one weir gate missing from skimmer at 4 ft depth. Provide required skimmer equipment.
	Not In Compliance	
	Violation Reference - CCR - 3136B	

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.

Overall Inspection Comments

Pool inspection conducted.

Signature(s) of Acknowledgement



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LA FITNESS	DATE 8/10/2015
LOCATION 14485 PIPELINE AV, CHINO HILLS, CA 91709	INSPECTOR Casey Salazar

A handwritten signature in blue ink, appearing to read "Casey Salazar".

NAME:
TITLE:

Total # of Images: 0