



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

|  |                            |                                 |  |                                       |
|--|----------------------------|---------------------------------|--|---------------------------------------|
| FACILITY NAME<br><b>PALM COURT APARTMENTS</b>  |                            | DATE<br><b>8/31/2015</b>        | REINSPECTION DATE<br><b>Not Specified</b>        | PERMIT EXPIRATION<br><b>3/31/2016</b> |
| LOCATION<br><b>8560 OLEANDER AV, FONTANA, CA 92335</b>   |                            |                                 | INSPECTOR<br><b>Isaac Gebreslassie</b>           |                                       |
| MAILING ADDRESS<br><b>8560 OLEANDER AV, FONTANA, CA 92335</b>  |                            |                                 | IDENTIFIER: Pool                                 |                                       |
| <input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT |                            |                                 | SERVICE: 001 - INSPECTION - ROUTINE              |                                       |
| TIME IN<br><b>1:14 PM</b>  | TIME OUT<br><b>2:04 PM</b> | FACILITY ID<br><b>FA0005337</b> | RELATED ID<br><b>PR0013835</b>                   | PE<br><b>3620</b>                     |
|  |                            |                                 | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE |                                       |
|  |                            |                                 | ACTION: 01 - NO FURTHER ACTION REQUIRED          |                                       |

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.



**96**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

|                   |
|-------------------|
| Ideal             |
| In Compliance     |
| Not in Compliance |



|                     |         |
|---------------------|---------|
| temperature (°F)    | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 63      |
| volume (gal)        | 22,800  |
| area (sq ft)        | 760     |
| occupancy           | 38      |

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K548 Equipment - General Requirements - System Description**

|                           |  |  |
|---------------------------|--|--|
| <b>POINTS</b><br><b>1</b> | Compliance Date: Not Specified         | <b>Inspector Comments:</b> Observed float assemblies missing from skimmers. Provide both skimmers with float assemblies. |
|                           | Not In Compliance                      |  |
|                           | Violation Reference - CCR 24 - 3123B.1 |  |

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The system shall consist of pumps, filters, chemical feeders, skimmers or perimeter overflow systems, valves, pipes, connections, fittings and appurtenances.

**36K574 Maintenance – Test kit**

|                           |                                   |  |
|---------------------------|-----------------------------------|--|
| <b>POINTS</b><br><b>1</b> | Compliance Date: Not Specified    | <b>Inspector Comments:</b> Provide test kit to monitor daily chemical balance of pool water. Observed missing. |
|                           | Not In Compliance                 |  |
|                           | Violation Reference - HSC - 65529 |  |

**Violation Description:** The pool operator shall maintain a test kit for measuring the disinfectant residual, pH, and, if used, cyanuric acid concentration at the public pool. This test kit shall be available for use by the pool operator and the enforcing agent at all times the public pool is in use. The chlorine or bromine test kit shall be the diethyl-p-phenylenediamine (DPD) type or otherwise be capable of testing free-halogen residual.



## Public Health

### Environmental Health Services

#### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

|  |  |
|--|--|
| FACILITY NAME<br><b>PALM COURT APARTMENTS</b>          | DATE<br><b>8/31/2015</b>               |
| LOCATION<br><b>8560 OLEANDER AV, FONTANA, CA 92335</b> | INSPECTOR<br><b>Isaac Gebreslassie</b> |

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K576 Maintenance – Operation/Incident records

**POINTS**  
**1**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC - 65523

**Inspector Comments:** Provide record of test results on a daily basis and maintenance of mechanical and/or electrical pool equipment as they happen. Observed test results to be not on a daily basis.

**Violation Description:** The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

#### 36K582 Maintenance - Public pool site maintenance

**POINTS**  
**1**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC - 65535

**Inspector Comments:** Observed flow meter stuck. Repair/replace.

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

#### Overall Inspection Comments

No summary comments have been made for this inspection.

#### Signature(s) of Acknowledgement

A handwritten signature in blue ink, appearing to read "Gerie".

NAME: Gerie  
TITLE: manager

Total # of Images: 0