





Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SUNRISE PARK			DATE 7/21/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2016
LOCATION 26335 SNOWDEN AV, LOMA LINDA, CA 92354			INSPECTOR Veronica Vazquez		
MAILING ADDRESS PO BOX 1510, UPLAND CA 91785			IDENTIFIER: Pool		
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 008 - INSPECTION - ATTEMPTED		
TIME IN 11:40 AM	TIME OUT 11:46 AM	FACILITY ID FA0008375	RELATED ID PR0014591	PE 3620	RESULT: 00 - NOT APPLICABLE
ACTION: 00 - NOT APPLICABLE					

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	16

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed pool gate locked. Contacted operator. Pool operator is unable to provide key to pool area. Will reinspect.
	Not In Compliance	
	Violation Reference - HSC	

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

Call Veronica Vazquez at (800) 442-2283 with questions.

Signature(s) of Acknowledgement

NAME:
 TITLE:
 Total # of Images: 0