



RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

FACILITY NAME VILLAGE ON THE GREEN APARTMENTS				REINSPECTION DATE Not Specified	INSPECTOR Bennetta Betbadal	DATE 9/22/2015
LOCATION 9400 FAIRWAY VIEW PL, RANCHO CUCAMONGA, CA 91730				PERMIT EXPIRATION	IDENTIFIER: None	
TIME IN 10:15 AM	TIME OUT 10:43 AM	FACILITY ID FA0014399	RELATED ID SR0069944	PE 3716	SERVICE: 126 - PLAN CHECK FIELD INSPECTION RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 03 - REINSPECTION REQUIRED	

RECREATIONAL HEALTH PLAN CHECK - PInCk Pool Minor Remodel - all

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

37K510 Plans - Preliminary Inspection

Compliance Date: Not Specified **Inspector Comments:** Pre-plaster inspection.
Not In Compliance
Reference - Reference Number - SBC Policy Authorized to plaster the spa.
Call for final inspection.

Description: Preliminary inspection

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:
Total # of Images: 0