



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME AGUA FRIA MUTUAL SERVICE				REINSPECTION DATE Not Specified	INSPECTOR Yvette Velasco	DATE 11/5/2015
LOCATION 725 GRASS VALLEY RD, BLUE JAY, CA 92317				PERMIT EXPIRATION 12/31/2015	IDENTIFIER: Pool	
TIME IN 10:31 AM	TIME OUT 10:43 AM	FACILITY ID FA0007318	RELATED ID PR0014643	PE 3620	SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
				RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU		
				ACTION: 03 - REINSPECTION REQUIRED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	90
volume (gal)	43,470
area (sq ft)	No Data
occupancy	48

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K994 Reinspection

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: During the last routine inspection the pool was observed green and the pool was closed.

Observed closure sign ripped off of front gate. A new closure sign was posted at the front gate. Observed front gate locked and no one on site. Observed no key provided. Observed pool green. Inspector contact Neva Trevithick, the previous secretary for the pool, at the phone number provided on file. Neva stated that she has been unable to contact the owner. A copy of the first routine inspection was sent via certified mail to the postal address on file as well as the owners address on file. No notification to verify that the mail was delivered has been received.

Facility will remain closed at this time. Inspector will attempt to an inspection at a later date. Please note that third inspections are billable at a rate of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122. Ensure to contact the Division of Environmental Health at 1-800-442-2283 in order to address the issue of the green pool.

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0